

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
110601	5/31/01	AC	The AC needs to stay on 24 hrs a day, and seems to be turned off at night. The material that is worked within this area cannot be worked with when it is too hot. Engineering is having problems with certain materials out of this area.
110645	5/31/01	Vents	Replace bad bearings in scrubber exhaust fan oh 1, vent #22
110663	5/31/01	AC	The temp in the clean room is too high. The current temp is 81 degrees. What I need is for someone from maintenance to come over and adjust the temp. This is work stop.
110695	5/31/01	AC	AC is not working and smells like it is burning!
110710	5/31/01	AC	Check oil level in Trane compressors and record readings each day. 6.3.658
110711	5/31/01	AC	Check operation of chillers. Take and record readings each day. 6.3.658
110712	5/31/01	AC	Check operation of chillers. Take and record readings each day. 6.3.658
110713	5/31/01	AC	Check operation of chillers. Take and record readings each day. 6.3.658
110714	5/31/01	AC	Check operation of chillers. Take and record readings each day. 6.3.658
110729	6/1/01	AC	AC inoperable in the 9630 training conf room/office. We cannot conduct classes without an AC. This unit has been down 3 to 4 times in the past week. This system is definitely needs checking to prevent continued unreliable service. Thanks.
110732	6/1/01	AC	Please check out AC system in bldg 133. Very hot and muggy. No AC! Thank you!
110733	6/1/01	AC	RCA room-chill water unit leaking water
110743	6/1/01	AC	Request the AC in bldg 4470's conference room be repaired, is not working. I put in trouble tickets last year for the same problem. We had 30 people in the room this morning and it was extremely uncomfortable. Possibly under warranty.
110750	6/1/01	AC	Shop 96331 work area unbearably hot
110765	6/1/01	AC	T2 won't go cold/work stop/
110767	6/1/01	AC	Extremely hot office in front of bldg 4033
110774	6/1/01	AC	AC is not working
110779	6/1/01	AC	Check operation of window type AC unit, not cooling, located in 65100 office.
110802	6/1/01	AC	Replace low pressure switches as required and filters in machine shop AC bldg 137
110807	6/1/01	AC	Repair water condensation problem in area
110811	6/1/01	AC	Controlled environment not controlled in E2/C2 bonding room. Heat is on and temperature is well above limits.
110826	6/4/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
110830	6/4/01	AC	No AC in mixing room to hot to mix work stoppage.
110840	6/4/01	AC	Replace steam valves on front office AC unit
110842	6/4/01	AC	Temperature out of tolerance in calibration lab. Work stoppage.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
110843	6/4/01	AC	Extremely dirty air exchange filters.
110845	6/4/01	AC	Bldg 4224 restroom wash water is scalding hot. This is recurring problem. How many people have to get burned before this is fixed?
110850	6/4/01	AC	Turn off AC blowers/
110851	6/4/01	AC	Extremely dirty air exchange filter
110853	6/4/01	AC	Rubber room. Still very, very cold. Someone came and adjusted the thermostat, but it is still too cold.
110857	6/4/01	AC	Change bad compressor/work stop
110865	6/4/01	AC	Repair controls in the eatery AC 66 degrees in the room
110878	6/4/01	AC	No AC in avionics. They say already too hot in that section to work, AC was out all weekend. (not the unit that usually goes out) call POC for details, if needed.
110880	6/4/01	AC	Hot water is off in the men's head, across from the travel office
110885	6/4/01	AC	Hot air blowing into bldg 4470 conference room from air vents.
110887	6/4/01	AC	AC not working in area p507 (control room for test cell 5/6)
110898	6/4/01	AC	No hot water, hot water required to wash penetrant off parts. Currently unable to do so. Please check and get some hot water ASAP. Thank you
110916	6/4/01	AC	Problem has been reported before, thermostat is not working correctly. The system and thermostat is completely off. Location is the store side of ASKARS.
110923	6/4/01	AC	Fuel control test stand, T64 mech #1 chiller will not bring temp down.
110930	6/4/01	AC	Clean grills and replace bad tile
110936	6/4/01	AC	R12 expansion valve inoperable in T2 system on T58 # 5 manual test stand. Work stoppage
110944	6/4/01	AC	Won't go down to -25/work stop
110952	6/4/01	AC	Won't go down to -25/work stop
110958	6/5/01	Vents	Check operation of exhaust fan on D106 system, stack number 654. Magnahelic gAuguste readings are very erratic. Filters have been checked and are ok. GAuguste has been replaced.
110960	6/5/01	Vents	Repair vent for chiller room behind bldg
110971	6/5/01	Vents	Exhaust fan in heat treat furnace room does not work.
110987	6/5/01	AC	The main AC in transportation does not work.
111007	6/5/01	AC	Please have someone look into AC problem in the upstairs back room. The AC unit is in a little room on the side of the bldg, we have been noticing a very stale odor coming out with the warm air. Climate controlled area, no windows. Need help please
111009	6/5/01	AC	Clean and disinfect AC ducts
111012	6/5/01	AC	AC unit in instrument bearing clean room inoperable. Work stoppage
111013	6/5/01	AC	T2 system inoperable on T58 fuel control # 1 manual test stand. Work stoppage

Ticket Number	Date	Problem Type	Description
111019	6/5/01	AC	Need high efficiency hypo-allergenic filter install in AC.
111021	6/5/01	AC	Leaking on the catwalk and material. Liquid seems to be coming from the ventilation. Safety hazard!!
111036	6/5/01	AC	T2 facilitation rig in ASE test area requires insulation.
111037	6/5/01	AC	AC inoperable in accessories test area.
111052	6/5/01	AC	This ticket for record purpose. No AC in bldg confirmed system down and reported this to AC mechanic.
111054	6/5/01	AC	Temperature in the office is 84 F (650) notified. The EMS computer indicates a chiller problem. Malfunction reported by division director (4.5.1)
111063	6/5/01	AC	Refrigerator in room 1180 isn't properly cooling. Call for access.
111068	6/5/01	AC	AC will not work in test cell...
111069	6/5/01	AC	Making tremendous noise.
111071	6/5/01	AC	AC not working. Very warm in shop. Please fix.
111074	6/5/01	AC	Need to change the AC filters in the office and break areas in bldg 154a the GSE section.
111086	6/5/01	AC	AC on roof is leaking water onto LIS stacker#5 conveyor work station located next to interior roll-up door material section
111090	6/6/01	AC	AC not working in the training office of bldg 133. We cannot conduct classes without AC, thereby, we are at a work stoppage until this is fixed, or a remedy to provide AC is provided. Thanks.
111093	6/6/01	AC	AC not working in metallurgical lab area.
111094	6/6/01	AC	AC not putting out cold air. (work stoppage) need controlled temp and humidity of adhesives used in shop.
111096	6/6/01	AC	No AC in the middle of the bldg
111098	6/6/01	AC	AC not working needs to colder for mixing room
111136	6/6/01	AC	Very warm in shop. AC not working properly. Please adjust to cool shop.
111145	6/6/01	AC	Hf furnace room very hot, heat running, please help
111146	6/6/01	AC	T2 system on the #1 T64 manual stand will not get cold. Work stop
111148	6/6/01	AC	Repair leak over chiller as per
111157	6/6/01	AC	Acclimated room. Work stoppage temp-78 humidity-80%. Cannot work when temp is over 72 and humidity is over 50%. Back up unit is not working well enough to keep the temp and humidity low enough.
111165	6/6/01	AC	AC unit number two in hot air channel test area not cooling properly.
111176	6/6/01	AC	AC leaking in office, suspect clogged drain line
111177	6/6/01	Vents	Replaced belts on 1798-5, 1798-7, 1798-9. Discrepancies found while performing PMs on mct 105780.
111180	6/6/01	AC	The AC is not working properly. The air being circulated is not very cool. Request this system be checked. We are still at a work stoppage until the room temperature can be made adequate enough to conduct class.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
111183	6/6/01	AC	Please repair the AC in can 1377 this is the computer lock up
111191	6/6/01	AC	Bldg 4225 computer room unit # 22-313a will not reset high temp alarm. Unit is off line and room temp is getting too high (85+) for computer systems to function correctly.
111192	6/6/01	AC	Leaking backflow preventer located above stand CIN0444 back side of bldg to left of cooling tower.
111196	6/6/01	AC	Temperature in office area of bldg is not cooling properly.
111210	6/7/01	AC	AC system off again. Almost 90 degrees in office area. Help!
111213	6/7/01	Vents	Replace worn pulleys and bad bearings. Discrepancy found while performing PM on link #V750571, mct #107019.
111214	6/7/01	Vents	Repair bearings. Discrepancy found while performing PM on link #V750588, mct #107019.
111215	6/7/01	AC	HVAC unit is not cooling.
111216	6/7/01	AC	Bldg 4033, area G10 (H-46 avionics team). AC in bldg is fine; however, area G10 is uncomfortably warm and has been for some time.
111225	6/7/01	AC	AC not working in mixing room work stoppage
111232	6/7/01	AC	AC is not running. It is very humid and the temperature is rising.
111234	6/7/01	AC	Attn: AC will not run in test cell...
111239	6/7/01	AC	AC in hf furnace control room is not keeping room cool. Note: this is a standalone freon heat pump unit.
111240	6/7/01	AC	Help! We have no, none AC in here. You cannot breathe in this air. Please come check. Fans are running wide open, but we have no windows that will open. Help!
111242	6/7/01	Vents	Troubleshoot vent 133-66. Unit will not turn on. Discrepancy found while performing PM on link #V775350.
111245	6/7/01	AC	AC vents in balance room are closed. No air can come through them. Please open vents.
111252	6/7/01	AC	Leak in the ceiling, ceiling tiles beginning to fall down. Water coming out of the ceiling is cold water
111268	6/7/01	AC	AC continues to not pump cool air. Temp right now at 9:30am is 80 degrees. Please have someone come check. AC man came last week, but still have the same problem. Employees are complaining of the heat.
111281	6/7/01	AC	Black lint like material is falling out of AC vents. Sample of the material is available in the supervisor's office. Refer to ticket #100558. This is not a duplicate.
111289	6/7/01	AC	Temp has exceeded the limits for electronic calibration. Repair as soon as possible
111293	6/7/01	AC	Make repairs in penthouses as per list.
111299	6/7/01	AC	AC still not working. Third call. Please fix.
111319	6/7/01	AC	Test bench electronic cabinet running really hot purge air causing electronic problems
111320	6/7/01	AC	Check the air handler motor. A belt was found on the floor., he has the belt he found at his desk
111332	6/7/01	AC	Need high efficiency hypo-allergenic filter install in AC.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
111333	6/7/01	AC	Test bench electronic cabinet running really hot purge air causing electronic problems
111337	6/7/01	AC	AC units in hot air channel not putting out any cold air P/n 65923006872
111341	6/7/01	AC	Test bench electronic cabinet running really hot purge air causing electronic problems
111354	6/7/01	AC	Check oil level in Trane compressors and record readings each day. 6.3.658
111355	6/7/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
111356	6/7/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
111357	6/7/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
111358	6/7/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
111368	6/8/01	AC	Over 90 degrees in office spaces. HELP! ASAP!
111386	6/8/01	AC	Guys we're dying in here. Yesterday afternoon it cooled down and we were doing fine. Now, this morning it's hot enough to melt marshmallows in here. Please come check. Something's really wrong here.
111431	6/8/01	AC	Need coolant checked in woton
111432	6/8/01	AC	AC vent for code 6.2.960 division director's office, is not connected to any duct work. This seems to be a common problem on Mezzanine A, please check all vents in area.
111442	6/8/01	AC	Chill water not working on test stand. 4 & 5 test cell.
111449	6/8/01	AC	Chill water not working on test stand. 4 & 5 test cell.
111476	6/8/01	AC	Chill water not working on test stand. 4 & 5 test cell. (could not follow up on nightshift because there was not an operator.).
111481	6/11/01	AC	AC is off again. Can we get this fixed for good????? This is becoming an every day ticket item.
111482	6/11/01	AC	CRU #2 in computer room #107 has an air flow loss alarm and is not cooling. This has lead to a work stoppage.
111483	6/11/01	AC	AEP area, the fan is loose, it is making a loud noise, and the room has flooded over the weekend. Work stoppage.
111493	6/11/01	AC	T2 system blowing smoke/work stop
111502	6/11/01	AC	AC in lobby and second floor not working. AC in computer room not cooling as it should.
111505	6/11/01	AC	Need AC in 4 & 5 test cell.
111507	6/11/01	AC	Cooling unit for masking area not working. It also appears the cooling unit for hard anodize may not be working right and all this is tied together. Chillers thanks
111508	6/11/01	AC	Cannot achieve -15 degrees T2 temperature on T64 # 2 manual test stand. Work stoppage
111515	6/11/01	AC	O.k. guys. The air-conditioning has bit the dust again, I think. The air is barely stirring in here. Please check.
111540	6/11/01	AC	AC from our tech pub hooch is leaking water onto the walkway in the H-46 hangar (in front of the SBU office). Possible slip hazard.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
111561	6/11/01	Vents	Exhaust blower 137-v313 blower casing is rusted out with a large hole in bottom of housing. Please repair or replace
111580	6/11/01	AC	Repair AC unit in bearing shop
111593	6/11/01	AC	Replace sensor pump as per instruction
111594	6/11/01	AC	Repair coupling on chill water pump
111595	6/11/01	AC	Repair water flow switch as per instruction
111596	6/11/01	AC	Repair/replace bearings in the pump for the condenser
111597	6/11/01	AC	Assist York chiller rep,
111598	6/11/01	AC	Provide pre OT shift for production 06-11-01
111599	6/11/01	AC	Repair oven room
111600	6/11/01	AC	Repair AC in motor control center on roof. Urgent request, vent system tripping.
111602	6/11/01	AC	Replace sensor pump as per instruction
111603	6/11/01	AC	Repair coupling on chill water pump
111604	6/11/01	AC	Repair water flow switch as per instruction
111606	6/11/01	AC	Repair/replace bearings in the pump for the condenser
111607	6/11/01	AC	Assist York chiller rep
111608	6/11/01	AC	Provide pre shift OT for production 06-11-01
111611	6/11/01	AC	Repair AC
111630	6/12/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
111659	6/12/01	AC	Roof leaking from AC overflow pan
111662	6/12/01	AC	Repairs needed.
111664	6/12/01	AC	Cut pipe as per my instructions
111671	6/12/01	AC	T2 motor is inoperable on ASE test stand (T64) # 4. Work stoppage attn:655 refrigeration maintenance
111683	6/12/01	AC	AC unit in lofting area has alarm going off. Not cooling at all. Need assistance ASAP. Thanks
111687	6/12/01	AC	Filters on Liebert AC unit located in the TTU-205 calibration room below Mezzanine F, need to be changed.
111710	6/12/01	AC	Repair AC unit at rear of shop.
111724	6/12/01	AC	Humidity in shop so high cannot run critical equipment.
111741	6/12/01	AC	AC in hot air channel will not run.
111742	6/12/01	AC	AC in hot air channel will not run.
111747	6/12/01	AC	No hot water in bonding room, possible work stoppage
111758	6/13/01	AC	Assist the pump alignment. Secure chillers as needed report when complete. Thanks

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
111762	6/13/01	Vents	Replace worn pulleys and bad bearings. Discrepancy found while performing PM on link #V750571, mct #107019.
111763	6/13/01	AC	Mezzanine B telephone room-AC is running too hot. This is a climate-controlled room and it is now 80 degrees.
111775	6/13/01	AC	AC unit in AC metal store is leaking water onto floor. Safety hazard
111803	6/13/01	Vents	Exhaust blower 137-v313, v314, v315 blower casing is rusted out with a large hole in bottom of housing. Please repair 3 exhaust vents as per D&J conversation
111818	6/13/01	AC	Air handler-compressor in the air handler is broken, work stoppage
111833	6/13/01	AC	AC not working. Very warm in shop. Please repair.
111841	6/13/01	AC	Repair refrigerant air dryer in compressor room outside bldg 1665.
111843	6/13/01	AC	The AC leaks when it shuts down. Mezzanine A
111852	6/13/01	AC	Thermostat message states clean filter needed
111866	6/13/01	Vents	Exhaust vent 137-307 located in the, ("cave"), propeller shop is in operable.
111873	6/13/01	AC	Steam in bldg 245 old paint area needs to be turned off. It's hot!
111882	6/14/01	AC	Steam in bldg 245 old paint area needs to be turned off. It's hot!
111899	6/14/01	AC	Urgent, I need someone to go on the roof and look at the AC for the Sermetel room. We are unable to spray any Sermetel at this time. We need you to do this ASAP. Thank you...
111912	6/14/01	AC	Condensations leaking from AC in each office.
111913	6/14/01	AC	T2 system will not achieve -25 degrees on T58 manual fuel control test stand # 5. Work stoppage
111944	6/14/01	AC	Request check on (3) roof AC units which control main computer room/lobby area/avionics area and change all filters in bldg receiving complaints about smell and various allergy problems.
111948	6/14/01	AC	Transverse hangar Mezzanine, where the old safety office used to be. AC-heating vents are dripping condensation on personnel and carpet.
111969	6/14/01	AC	Water leaking around the light fixtures, 3rd floor. She also said water was dripping from AC vent onto the division directors desk. The lights are not around a vent.
111983	6/14/01	AC	Check oil levels in Trane compressors and record readings each day
111984	6/14/01	AC	Check operation of chillers second shift take and record readings each day
111985	6/14/01	AC	Check operation of chillers second shift take and record readings each day
111986	6/14/01	AC	Check operation of chillers second shift take and record readings each day
111987	6/14/01	AC	Check operation of chillers second shift take and record readings each day
112015	6/15/01	AC	AC is out in the E2 bonding room, work stoppage
112023	6/15/01	AC	We have a leak in the GE reps office on Mezzanine D, bldg 133. Please address ASAP.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
112026	6/15/01	AC	Water dripping out of AC vents. Dripping on desk
112032	6/15/01	AC	ASE 5 computer purge air is hot and not cooling computer equipment and back of stand. Work stop
112039	6/15/01	AC	Water leaking around the light fixtures, 3rd floor. She also said water was dripping from AC vent onto the division directors desk. The lights are not around a vent. Investigate and repair if within monetary limit.
112039	6/15/01	AC	Water leaking around the light fixtures, 3rd floor. She also said water was dripping from AC vent onto the division directors desk. The lights are not around a vent. Investigate and repair if within monetary limit.
112040	15-Jun-01	Ventilation	Vent motor inoperable.
112047	6/15/01	AC	Perform PM on carrier AC model 39ED21 S/N 8141d3083231 located in hangar 53, near back entrance on the left. Filters clogged. Requirement identified by Griffin Electric while looking for another unit.
112054	6/15/01	AC	Odor, need aromatic filters installed please
112055	6/15/01	AC	Pipe new drain to drip fan under AC unit.
112074	6/15/01	AC	AC #3 in down stairs lab (computer room) is displaying a message "compressor #1 failure". The location number on the computer room door is 529.
112084	15-Jun-01	Ventilation	Vent motor kicked off line again since repairman visit.
112098	6/15/01	AC	Mezzanine 192 AC needs checked. It was blowing extremely cold air out and now has stopped. We don't know if it is frozen, but it is hot up here and on the 3rd floor above us.
112104	6/15/01	AC	T2 system on T58 manual fuel control test stand # 5 is cold and will not achieve 75 degrees. Work stoppage
112115	6/15/01	AC	AC in new area of shop blowing hot air.
112120	6/16/01	AC	Fixed Friday broke sat. We did the same last year. It was finally fixed in Jan.....
112121	6/18/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
112123	6/18/01	AC	AC not working in the E&E room
112125	6/18/01	AC	Leak in roof or AC system. Water in light fixture and on workbenches.
112134	6/18/01	AC	CO2 tank has a cooling system which may need a shot of freon. Please have someone look at this. Thanks
112144	6/18/01	AC	AC is not running - please send help.
112149	18-Jun-01	Ventilation	Reset vent motor. Won't start up EIN 127131031. 4 & 5 test cell
112159	6/18/01	AC	Cooling unit for hard anodize is down or not working properly. Thanks
112169	6/18/01	AC	AC still not working. Reference ticket number 111833 of 13 June.
112221	6/18/01	AC	Repair motor control center for clean room work stoppage
112225	6/18/01	AC	Repair electrical connector as per instructions work stoppage



Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
112226	6/18/01	AC	Start AC in clean room bldg 133
112229	6/18/01	AC	T2 electrical lead broke/work stop. Please have night shift come repair
112261	6/19/01	AC	Our office (PMA spaces) does not have AC this morning - please fix it.
112262	6/19/01	AC	T2 system inoperable on T64 fuel control # 1 manual test stand. Work stoppage
112278	6/19/01	AC	Blowing hot air
112280	6/19/01	AC	Temp has exceeded the limits for electronic calibration. Repair as soon as possible.
112281	6/19/01	AC	No AC in the eatery
112302	6/19/01	AC	Send someone to repair the eatery AC for the 5th time. Repair refrigerant leak. Replace filters and clean condenser ASAP. Contact before authorized payment.
112313	6/19/01	AC	Check AC for condensation that is wetting the ceiling tiles in the eatery
112345	6/19/01	AC	There is a yellow greasy fluid leaking from the AC. Located in the computer room.
112365	6/20/01	AC	AC unit in the computer room, Mezzanine G is leaking yellow fluid
112378	6/20/01	AC	AC is not working, compressor not coming on. His men work all day in the hot sun and need a place to cool off. Please expedite thank you
112395	6/20/01	vents	Repair #1 and #3 ceiling exhaust fans in can #1380
112397	6/20/01	AC	Check and repair AC as needed. About one to two days a week the shop bonding processes are down because the temperature, from the AC being out.
112402	6/20/01	AC	AC in office upstairs is not working.
112406	6/20/01	AC	AC in office upstairs is not working.
112409	20-Jun-01	Ventilation	Fix the two exhaust fans in the rear of can 1378. Replace any parts deemed necessary to get the fans operational.
112411	6/20/01	Vents	Request the vent in the men's head M-12 be cleaned and repaired. They have stopped running. This is an urgent request.
112457	6/21/01	AC	This is my daily trouble call on the AC. The prop shop supervisor will probably be putting in one soon since he won't be able to use his prep room.
112500	6/21/01	AC	Repair propane tank filling station.
112521	6/21/01	AC	One AC unit not putting out cool air like it should.
112552	6/21/01	AC	Check oil level in Trane compressors and record readings each day. 6.3.658
112553	6/21/01	AC	Check operation of chillers. Take and record readings each day. 6.3.658
112554	6/21/01	AC	Check operation of chillers. Take and record readings each day. 6.3.658
112555	6/21/01	AC	Check operation of chillers. Take and record readings each day. 6.3.658
112556	6/21/01	AC	Check operation of chillers. Take and record readings each day. 6.3.658

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
112569	6/22/01	AC	T2 won't go cold/work stop/
112592	6/22/01	AC	Same as ticket #12120, 112378 and 112457
112593	6/22/01	AC	AC hot moist air/climate controlled area work stoppage
112596	6/22/01	AC	Office 173 water is leaking from the AC and running across the door threshold. Safety hazard
112631	6/23/01	AC	Thermostat no reading correctly. Repair or replace
112638	6/25/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
112639	6/25/01	AC	T2 system inoperable on T64 # 1 manual test stand. Work stoppage
112640	6/25/01	AC	T2 system inoperable on T64 # 2 manual test stand. Work stoppage
112646	6/25/01	Vents	Everyday I come in, there are fine grains of black items on my desk coming from the vent. This is not good for me or my co-workers health that sits adjacent to me--causing us to cough a lot--please check to see if this is a health hazard.
112656	6/25/01	AC	AC not working properly, water dripping from pipes.
112689	6/25/01	AC	Work stoppage TE2 bonding room (controlled environment) temperature to low humidity to high.
112698	6/25/01	AC	AC in office is not working properly, too hot
112712	6/25/01	AC	AC not working in shop 96332 85 degrees in shop
112720	6/25/01	AC	Very cold in shop. Need a little heat mixed in.
112736	6/25/01	AC	Repair AC as per instructions
112737	6/25/01	AC	AC in bonding room at 1665 need repaired. Work stoppage!
112740	6/25/01	AC	T2 system will not achieve -15 degrees on T64 # 2 manual test stand. Work stoppage
112743	6/25/01	AC	T2 system will not achieve -15 degrees on T64 # 2 manual test stand. Work stoppage
112751	6/26/01	AC	61 degrees in shop this morning. Need a little heat added.
112753	6/26/01	AC	T2 system won't go cold/work stop/
112754	6/26/01	AC	Classroom #8 in facility will not cool.
112755	6/26/01	AC	Tank-184 cooling is not working-- this is a zinc nickel process and this is a real work stoppage thanks
112758	6/26/01	AC	AC not working.
112771	6/26/01	AC	AC filters are very dirty. AC is not working very good. Same problem as last summer. Thanks for any help.
112793	6/26/01	AC	AC is not working upstairs right front. Warm air is blowing from vents.
112802	6/26/01	AC	AC unit in the print shop, the line must be clogged because it is flooding the floor. This needs to be repaired ASAP for the floor will really be in bad shape in the am.
112858	6/26/01	AC	AC unit #2 in hot air flow channel test area has quit.
112876	6/26/01	AC	The AC located in the back of the computer room is leaking some type of oil. Was called in last week but no one worked on it.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
112878	6/26/01	AC	Repair AC thermostat in 610 conference room. Draft behind thermostat base or improper calibration of unit is causing extreme temp fluctuations.
112880	6/26/01	AC	Needs someone to open box in bonding room so QA can check temperature
112883	6/26/01	AC	Needs someone to open box in bonding room so QA can check temperature
112888	6/26/01	AC	AC in hot air channel not working
112894	6/26/01	AC	Wotan NC boring mill-spindle over heating-very hot!!!! Urgent!!! Shaft seal leaking on AC compressor, attn: shop 655.
112912	6/27/01	AC	Request AC be checked in this bldg very hot - even in the mornings. There are no windows in this bldg that can be opened for ventilation and by afternoons, heat is stifling.
112921	6/27/01	AC	Leak by the paint mixing booth, it is coming out of the air vent thanks this vent could be a forced air vent, not AC and hasn't been used in years. Leaking for about 1 1/2 weeks.
112923	6/27/01	AC	Bad seal in compressor all the freon leaked out
112924	6/27/01	AC	Window unit AC dripping on the stairway and the fan rubs against the housing when the paint classroom door is shut. This is located in the rubber room.
112929	6/27/01	AC	The AC system in the metallurgical portion of the bldg is not running.
112932	6/27/01	AC	Too warm in shop. Please turn AC back on.
112933	6/27/01	Vents	Exhaust fan #83-d58 will not work in welding shop. Work stoppage due to fumes
112963	6/27/01 6/27/01	AC	The air-conditioning filter needs changing, 20x20 The air-conditioning filter needs changing, 20x25
112969	6/27/01	AC	Replace overhead filters in clean room. (these are HEPA filters/inlet air ventilation/recessed in the ceiling.)
112997	6/27/01	AC	Very hot on one side of 2nd floor (training). Please lower temperature. Thank you!
112998	6/27/01	AC	High humidity problem in subject shop. Setup a temp/humidity chart for 48 hrs. Set outside air to 5% of re-circulated rate. Change filter. Clean coil. Check condensate drain pan and discharge line for blockage. Check refrigeration charge.
112999	6/27/01	AC	P3 buff & grind room down.... Work stoppage.... Suspect main pump filter screens clogged.
113009	6/27/01	AC	AC located in front section of the computer room keeps alarming and the "de-humidification" light keeps coming on. Please check since it's the only one we have left.
113011	6/27/01	AC	(Problem has been called in but wanted to put in a ticket for our records) AC located in the back of the computer room died.
113015	6/28/01	AC	Check for AC leak in ceiling. Ceiling tiles are wet. This problem was worked on before and is reoccurring.
113018	6/28/01	AC	Drain not working properly, water pooling on floor. Requested filter change yesterday, ticket # 112963
113031	6/28/01	AC	Adjacent to column. E20, overhead leak, next to bldg 133 lobby entrance
113033	6/28/01	AC	AC located in front section of the computer room keeps alarming and the "de-humidification" light keeps coming on. Please check since it's the only one we have left.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
113034	6/28/01	AC	High humidity problem in subject shop. Setup a temp/humidity chart for 48 hrs. Set outside air to 5% of re-circulated rate. Change filter. Clean coil. Check condensate drain pan and discharge line for blockage. Check refrigerant charge.
113036	6/28/01	AC	Very hot on one side of 2nd floor (training). Please lower temperature. Thank you!
113037	6/28/01	AC	AC is not working which makes the other one pull all the load and temperatures range from 73 - 82 degrees. The one that is working has a large amount of condensation every day (slip hazard).
113040	6/28/01	AC	T2 system on T64 # 1 manual test stand will not achieve -15 degrees. Work stoppage
113067	6/28/01	AC	T2 won't go cold/work stop
113081	6/28/01	AC	Window AC units in both guard shacks need their filters changed/general maintenance
113091	6/28/01	AC	AC units #'s 1 & 2 inoperable in hot air channel test area.
113100	6/28/01	AC	The AC in the 402 test cell control room is not cooling properly. The computers in the control room require proper climate control in order to work without overloading.
113104	6/28/01	AC	AC is broken and it is at least 85 degrees in here.
113105	6/28/01	AC	The AC is broken and it is at least 85 degrees in here.
113139	6/29/01	AC	Humming noise coming for AC unit.
113156	6/29/01	AC	The heat is on at the radiators next to the south side windows overlooking A Street upstairs in the bldg
113161	6/29/01	AC	Adjust manual damper on supply duct to increase air flow to division director's office.
113169	6/29/01	AC	Will someone please tell us the status on the AC in upstairs area. Please help, maybe we could have a big fan in the door way to blow air in. The big hanger is cooler than here, perhaps that fan might help until the AC is fixed. This is a enclosed area
113183	6/29/01	AC	Physically clean and replace all air filters and belts if necessary on air handling units 1, 2, 3, & 4. ASAP see before and after the job.
113211	6/29/01	AC	Make up air unit number-3 is not working. We need this up extremely hot in here thanks
113220	6/29/01	AC	Water leaking into Mezzanine C. Fix brick and flashing and replace ceiling tiles.
113221	6/29/01	AC	AC not working.
113227	6/29/01	AC	Investigate leak coming through ceiling tiles, 2nd level between the 2 cage areas
113232	6/29/01	AC	Check AC unit no output
113233	6/29/01	AC	Check oil level in Trane compressors and record readings each day. 6.3.658
113234	6/29/01	AC	Check operation of chillers and take readings each day on second shift. 6.3.658
113235	6/29/01	AC	Check operation of chillers and take readings each day on second shift. 6.3.658
113236	6/29/01	AC	Check operation of chillers and take readings each day on second shift. 6.3.658

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
113237	6/29/01	AC	Check operation of chillers and take readings each day on second shift. 6.3.658
113250	7/2/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
113251	7/2/01	AC	AC in front half of shop is not working properly. Set on 70 but is staying in 77 range most of the day. Very humid also. This has been for over one week.
113252	7/2/01	AC	Tank 184 is our zinc nickel tank. The cooling needs to be turned on. This is the second w/o first one was on 6/26/01. This is truly a work stoppage. Machine shop needs bushings plated for downed aircraft. Thanks
113260	7/2/01	AC	Fan not working on chiller unit. Work stoppage.
113264	7/2/01	AC	Check water leak from AC. Unit at bldg 4225
113268	7/2/01	AC	Condensation plug is clogged causing water to leak all over test stand/work stop
113273	7/2/01	AC	Make up air unit number-3 is not working---we need this up extremely hot in here thanks
113278	7/2/01	Vents	Repair exhaust fan and louvers in electrical vault
113294	7/2/01	AC	Open equipment room door so it can be painted. Remove equipment.
113313	7/2/01	AC	AC in the snack bar area is not working.
113341	7/2/01	AC	HVAC
113350	7/2/01	AC	Repair controls and remove steam coil for pressure check make repairs if needed and reinstall into unit
113355	7/2/01	AC	T2 won't go cold/work stop
113376	7/2/01	AC	Check air in bonding room. Freezing. Thanks.
113416	7/3/01	AC	Test stand 3012 FMU fuel control the high inlet fuel temp won't go down: work stoppage: (65200 told me this is work on the T-2 07/03/2001)
113423	7/3/01	AC	AC chilling unit on wotan low on freon. Needs recharging for continued use until replacement compressor is installed.
113439	7/3/01	AC	Ice machine in back aisle behind heat treat area is not working. It has a red warning light lit on the front panel. Thanks
113450	7/5/01	AC	Water leaking from ceiling in clean room staging area
113452	7/5/01	AC	No chill water/work stop
113460	7/5/01	AC	Need to change filters on outside AC
113461	7/5/01	AC	Set HVAC to 68 degrees in old NDI room. We want to have room temperature lowered for CMM equipment.
113463	7/5/01	AC	Water is leaking from ceiling by light fixture in men's restroom upstairs. Located above sinks.
113464	7/5/01	AC	We have no chill water in hazard test. Unable to run test stand for shop 96332. (work stoppage)
113466	7/5/01	AC	Request for inspection of leaks and replacement of stained ceiling tiles. Many tiles damaged due to the roof, window, ceiling leaks and AC problems. Approx. 47 tiles. Office and lab area.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
113494	7/5/01	AC	On-going problem, AC is not working temperature is 79 and above
113504	7/5/01	AC	AC unit sounds like bearing is going bad. A lot of noise coming from the unit
113518	7/5/01	AC	Water leaking from AC or roof/ceiling not sure but there is plenty of water. Sent 7/5/01 at 1310.
113526	7/5/01	AC	Seal hole directly behind thermostat in 610 conference room. See for details.
113530	7/5/01	AC	Mezzanine G. Alarm going off, AC, dehumidification
113534	7/5/01	AC	AC not working in H-46 blade repair section of bldg
113539	7/5/01	AC	Check oil level in Trane compressors and record readings each day. 6.3.658
113540	7/5/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
113541	7/5/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
113542	7/5/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
113543	7/5/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
113555	7/6/01	AC	Water all over the floor, going under other floor where telephone cables and cable splices are, if they get wet, nobody will have telephone service AC drain clogged
113556	7/6/01	AC	AC unit for masking area is leaking. Unit is located over the main aisle in front of the chrome process area. Thanks
113560	7/6/01	AC	Acs power switch is on but they are not working, this situation has been going on for 2 weeks, please we need help with this.
113561	7/6/01	AC	Mezzanine E computer room compressor - coil iced over and belt is off the motor pulley
113571	7/6/01	AC	AC draining water down onto electrical storage racks! Possible shock hazard!
113587	7/6/01	AC	Ref. Ticket#113518 sent 7/5/01:water leak had subsided but has started up again; this is in the area of a 28vdc power supply and is also a slip hazard. Sent 7/6/01 at 1000hrs.
113597	7/6/01	AC	Repair leak in chiller.
113608	7/6/01	AC	Repair AC in bldg 4032.
113617	7/6/01	AC	AC vent is leaking
113620	7/6/01	AC	Scalding, hot water coming out from the AC unit. Needs to be done ASAP
113634	7/6/01	AC	ASE num 2 stand no T2 air
113640	7/9/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
113643	7/9/01	AC	Filters need changed in tach room and DITMCO room please. Thank you
113644	7/9/01	AC	Ttu205 room under Mezzanine F AC inoperable. Climate controlled room work stoppage
113647	7/9/01	AC	Cooling unit for hard anodize process is not working. This shuts down that process which is a work stoppage----- thanks

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
113654	7/9/01	AC	T2 system inoperable
113655	7/9/01	AC	Leak in the T2 system has caused test stand to be inoperable
113656	7/9/01	AC	AC blowing water.
113665	7/9/01	AC	Bonding room's humidity is to high. Work stoppage!
113667	7/9/01	AC	Ice machine outside back door of shop is not working red light is on and no ice coming out. Thank you
113669	7/9/01	AC	Replace safety switch on AC unit
113690	7/9/01	AC	One fan in a two-fan system is not working, bldg does not stay cool, also please check and change filters. Thank you
113695	7/9/01	AC	Replace compressor on wotan lathe start 7-10-01
113710	7/9/01	AC	AC is not working properly. The thermometers in the office are reading 82%. The air is not cold.
113717	7/9/01	AC	Please check AC. Condensation is not running out the pipe as it should. It is running out around the AC itself. Please check
113719	7/9/01	Vents	Vents at mixing table in clean room are not operating. Safety hazard. Repair ASAP
113720	7/9/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
113723	7/9/01	AC	The ice machine in back aisle behind heat treat area is still not making ice... See ticket #113439 on 7/3/01. Same problem red warning light lit on front panel. It is an awful hot time not to have ice for shop coolers! Please expedite, thanks
113741	7/10/01	AC	AC unit number two in hot air test channel area not working properly. Repair as required.
113742	7/10/01	AC	6.3.65200 branch office AC not working. Need support fast! Thanks
113743	7/10/01	AC	Repair AC unit in office
113746	7/10/01	AC	Water chiller on agie wire cut machine not operating causing machine shutdown.
113806	7/10/01	AC	The air handling unit for the downstairs AC unit is leaking again. Late last week it began leaking and was fixed. The problem is this leak is over the main aisle so it causes a hazard. Please fix ASAP thanks
113809	7/10/01	AC	AC not working maintenance said system is plugged up and installed wrong Williams Contracting installed this system maybe they should check it out and fix it send large fan please help thanks
113812	7/10/01	AC	AC unit number two in hot air test channel area not working properly. Repair as required.
113813	7/10/01	AC	The AC in lathe room needs to be turn on
113842	7/10/01	AC	Wotan hydraulic overheating machine keeps shutting down. Thanks (possible AC unit)
113843	7/10/01	AC	AC is not working in mixroom work stoppage
113844	7/10/01	AC	Both AC in hot air channel blowing hot air. 65923012028
113847	7/10/01	AC	T2 system will not achieve -15 degrees on T64 # 2 manual fuel control test stand. Work stoppage

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
113856	7/11/01	AC	Making loud noises like it ready to take off and fly. Need ASAP as no windows "please"
113857	7/11/01	AC	AC in waiting room needs filter cleaned
113871	7/11/01	AC	The cooling unit on our hard anodize process line is down again. The solution must be cooled to 40 degrees and it is 50+ at this time. Thanks
113876	7/11/01	AC	AC is not working in the eatery of bldg 133.
113878	7/11/01	AC	AC worked yesterday, AC fan is running but both units are not cooling the shop, temp is going up, 75 plus at 7:30 am. This is for two rooms, one room has to maintain cooler conditions to bond it above norm at moment.
113885	7/11/01	AC	AC is not working. This is a work stoppage because it cools the mixing room.
113900	7/11/01	AC	Need to replace filters.
113907	7/11/01	AC	The T2 system on mech. #1 T64 stand will not come on line. Cannot go hot or cold. Work stop
113915	7/11/01	AC	AC draining water down onto electrical storage racks! Possible shock hazard! Investigate problem and if it's just a stopped up drain, fix it.
113919	7/11/01	AC	Hot in shop. Need some cool air. AC not working properly.
113926	7/11/01	AC	2 AC ducts are leaking.
113936	7/11/01	AC	Please check the AC for the branch office
113938	7/11/01	AC	AC unit number one in hot air channel test area not working properly. Repair as required.
113941	7/11/01	AC	Please fix something to catch condensation coming from window unit AC. Water is running out in walkway posing a safety hazard (slipping). This is located on the blade line bldg 133
113942	7/11/01	AC	Condensation is forming in the overhead lights and dripping in floor located beside machine shop (old union office)
113943	7/11/01	AC	Window unit AC is leaking onto floor
113944	7/11/01	AC	AC needs to be turned down. It is too hot in the shop and people are overheating. Climate controlled area
113955	7/11/01	vents	Remove exhaust fan from x-ray processor and ceiling located in dark room.
113959	7/11/01	AC	Hydraulic over temp on wotan. Send to 65100 AC
113962	7/11/01	vents	Remove exhaust fan from x-ray processor and ceiling located in dark room.
113980	7/11/01	AC	Very hot on one half of 2nd floor (training side).
113993	7/11/01	AC	AC not working, temp in room is 80 degrees. Ticket number 113878 submitted at 0739am today.
114000	7/11/01	AC	Temp out of limits in master gage room.
114005	7/11/01	AC	AC for small lathe room not working.
114036	7/12/01	AC	We once again have leaking from the ceiling like we did 4 weeks ago. Also, after that repair, we were told the 8 damaged tiles would be replaced. They have not been replaced & we now have 10 damaged tiles. (I looked for a duplicate ticket)



Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
114046	7/12/01	Vents	Repair louvers on exhaust vents. Problems identified on PM cards #V22483, v22482
114048	7/12/01	AC	Assist in trouble shooting controls on AC in the front office area.
114074	7/12/01	AC	Office smells stagnant. It's been like this for about a week. Could he have a filter inserted in the AC vent to help the smell? (#114099 was cancelled, related problem, may need more than filter)
114080	7/12/01	AC	AC temperature not dropping to temperature indicated on thermostat. Work stoppage for mixing room.
114083	7/12/01	AC	Check cooling system on 100-ton carrier unit for proper operation. Contact for consultation
114087	7/12/01	AC	Ice machine in back aisle behind heat treat area is still not working. It has a red warning light lit on the front panel. This is a second request for repair.
114100	7/12/01	AC	Need AC serviced in bldg 423. Change filter etc...
114120	7/12/01	AC	Heat exchanger leaking water on ASE test stand # 2.
114179	7/13/01	AC	Need AC serviced in bldg 423. Filters need changing and unit needs cleaning.
114181	7/13/01	AC	Back of dining area ceiling in the snack bar is wet. Could be possible leaking AC.
114211	7/13/01	AC	Repair humidity controls on Mezzanine D HVAC unit.
114223	7/13/01	AC	T2 air having a hard time making 145
114230	7/13/01	AC	Check oil level in Trane compressors and record readings each day. 6.3.658
114231	7/13/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
114232	7/13/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
114233	7/13/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
114234	7/13/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
114248	7/16/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
114250	7/16/01	AC	AC leak in area, tiles are down and computers out of service. Water everywhere. Disaster
114251	7/16/01	AC	A very strong odor, sometimes smelling like oil/gas. The odor is so bad when the AC unit is running.
114252	7/16/01	AC	No AC in mixing room work stoppage
114253	7/16/01	AC	Water coming through the ceiling, tiles are falling down, and water all over the floor. This is in the upstairs area. Don't know if it is the AC or a water leak.
114259	7/16/01	AC	AC is not running - both the temperature and humidity are high.
114263	7/16/01	AC	The mech #1 T64 test stand T2 is inoperable work stop
114265	7/16/01	AC	Tank # 33 the hard anodize is not cooling. This is a work stoppage. Thanks
114266	7/16/01	AC	The AC unit in 423, 94304 side is not working.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
114285	7/16/01	AC	Old ASKARS section, AC is down.
114289	7/16/01	AC	AC upstairs is leaking. Employee cannot grind blades. Work stoppage.
114311	7/16/01	AC	Repair AC unit on Mezzanine J
114319	7/16/01	AC	Need AC air filters changed on three units.
114336	7/17/01	AC	T2 air having a hard time making 145
114376	7/17/01	AC	AC in ordnance shop not operating. Must be kept climate controlled for parachute packing purposes. Please have this looked at ASAP.
114387	7/17/01	AC	Refrigeration unit needs recharge, calibration personal in work stoppage
114395	7/17/01	AC	Refrigerator not cold enough.
114401	7/17/01	AC	Repair the vav damper and controls in office. Office is always hot during summer months. Set point on controller in office is 70 degrees F. Actual temp is approx 80 degrees F.
114423	7/17/01	AC	AC in one area over 80 degrees. NE side of the bldg, office area. Please check it out.
114434	7/18/01	AC	Very warm in shop again. Need AC adjusted.
114459	7/18/01	AC	No chill water in the RCA room.
114470	7/18/01	AC	Compressor on unit in exposure room will not come on.
114472	7/18/01	AC	T58 mech #5 test stand has no chilled water the fuel temp is over 100 degrees.
114514	7/18/01	AC	We need the air turned on in the new production control area. We don't know if the problem is control switch, or power.
114516	7/18/01	AC	Water leaking through the ceiling. (Nelson Contracting said it is a pipe leak, or drain line coming from an AC) it is leaking in the compressor room.
114520	7/18/01	AC	Clean clogged unit and install filter racks.
114528	7/18/01	AC	Having a problem with the #1 AC unit in shop 93552, located in the ramp bldg in 137. AC stopped blowing cold air this morning. I think the belts are loose because it's making a squealing noise.
114544	7/18/01	AC	AC unit #2 in hot air channel test area inoperable. Repair as necessary.
114554	7/18/01	AC	AC not working in hot air channel room.
114573	7/19/01	AC	The heat is turned on!!!! Must be 90 degrees in shop area. Possible safety hazard just to be in here. Please turn on AC!!!
114575	7/19/01	AC	The heat is own in this area, it has been hot all week but this is going a little far....please fix our AC
114588	7/19/01	AC	A week ago today we submitted 114026 for a recurring leak (#112039). Leak was repaired. New tiles installed 2 days ago. Today there is a leak again & 3 of the new tiles are wet. (was an AC leak on previous ticket)
114590	7/19/01	AC	AC in the snack bar area is inoperable.
114591	7/19/01	Vents	Repair 5 hp fan motor on vent in transfers hanger
114624	7/19/01	AC	AC not working in test cell. #2 test cell

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
114641	7/19/01	AC	Pneumatics air dryer inoperable. Tripping breakers.
114642	7/19/01	AC	Add diffusers and repair HVAC unit under Mezzanine A
114646	7/19/01	AC	Water is leaking really bad from AC duct in front of small autoclave. Repair ASAP.
114663	7/19/01	AC	Hot in office, what air we are feeling is hot. Thermostat registers 84/85.
114671	7/19/01	AC	Avionics office has a bad leak, water coming down from inside the wall and is flooding the floor. If it rains tonight, it will really be bad.
114701	7/19/01	AC	Check oil level in Trane compressors, take and record readings each day. 6.3.658
114702	7/19/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
114703	7/19/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
114704	7/19/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
114705	7/19/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
114725	7/20/01	Vents	Repair the pneumatic tubing to the magnahelic gAugustes on the roof.
114732	7/20/01	AC	Temp in our office is 78 and rising---need relief.
114770	7/20/01	Vents	Replace belt on # 26 exhaust vent
114774	7/20/01	AC	Replace bad coupling on pressure switch on HVAC unit
114810	7/21/01	AC	L/E mod room AC is out this is a climate control room work stoppage
114813	7/23/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
114819	7/23/01	AC	2nd deck, water leak right in front of the eatery door area. Buckets were put under the leak on Saturday. Ceiling tiles will need to be replaced after the leak is fixed.
114821	7/23/01	AC	No AC
114828	7/23/01	AC	Remove cardboard block from AC vents in QA office bag area
114840	7/23/01	AC	AC or roof still leaking water overhead in 94206. Request repair and replacement of ceiling tiles that have been destroyed by resulting water damage and replacement of ceiling tiles removed for modifications and repairs in shop work areas. Sent 7/23
114872	7/23/01	AC	Water in air compressor head.
114895	23-Jul-01	Ventilation	Exhaust fan in the silver recovery room is inoperable.
114896	7/23/01	AC	AC duct over desk is dripping water
114908	7/23/01	AC	AC not working in office please help (could be a duplicate ticket, AC work being done in this bldg on ticket #114663)
114915	7/23/01	AC	Still warm in shop. Can we get some AC back on?
114925	7/23/01	AC	The access door on the ice machine is broken and falls off when it is opened. It is unsafe and must be handled with extra care. Some one could hurt themselves.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
114927	7/23/01	AC	The #1 AC unit in shop 93552, located in the ramp bldg (137) is blowing out only warm air again. Was called in last week and someone came to fix it, but it's out again this week.
114931	7/23/01	AC	Comfort air down in hydraulic shop area. Thanks
114942	7/24/01	Vents	Exhaust vent 137-332 located in the propeller shop E2/C2 rubber room is not working. Needed to mix chemicals for rubber repair on blades.
114945	7/24/01	AC	Assist in repair of AC unit at bldg 143.
114966	7/24/01	AC	Repair AC for 65900 area bad compressor
114970	7/24/01	AC	AC in the main bonding is leaking in bonding room.
114982	7/24/01	AC	Dirty room is very hot in fiberglass shop. Please adjust thermostat ASAP.
114992	7/24/01	AC	Repair or replace condensate pump behind ice machine in break room
114998	7/24/01	AC	Water leaking from ceiling in vestibule area next to shop. POC: supervisor
115002	7/24/01	AC	AC in 95446 office does not cool.
115004	7/24/01	AC	The drain for the AC unit may be stopped up causing water in the floor. See for location of unit
115017	7/24/01	AC	Ref ticket 113571 AC leaking water onto electrical storage unit again got a mess going on downstairs. Need help ASAP. Thanks
115051	7/24/01	AC	AC in shop hooch needs servicing. It is having trouble keeping office cool.
115078	7/24/01	AC	4 & 5 test cell no AC
115079	7/24/01	AC	No AC in shop 96332 . 85 degrees
115082	7/24/01	AC	Check AC for shop not cooling shop.
115104	7/25/01	AC	AC in shop is inoperable please send help!!!!!!
115105	7/25/01	AC	Need someone to look at the cooling unit for our CO2 tank. It may be the electric motor which runs the fan.
115110	7/25/01	AC	AC is on but not cooling.
115117	7/25/01	AC	Change filters in this air handling unit. Thank you. See for details.
115123	7/25/01	Vents	Ventilation duct fan in one of the welding booths cuts off by itself after about one minute use. (welding school)
115129	7/25/01	AC	Water dripping from overhead air vents onto floor/safety issue
115132	7/25/01	AC	The AC does not seem to be working properly. Half the bldg upstairs is cool (it is so cool that moisture is on the windows) and the other half is warm (it is so warm and humid the employees have to run fans).
115136	7/25/01	AC	Test stand needs freon
115137	7/25/01	AC	Ice machine between areas 1007/1006 not manufacturing ice.
115138	7/25/01	AC	Leak in the ceiling at the head of stairs in Mezzanine A. They cannot tell if it is a roof leak, pipe leak or AC leak. Investigate and determine the cause of the leak and repair if possible.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
115140	7/25/01	AC	Test stand needs freon
115148	7/25/01	AC	AC. Unit has a loud noise sin: 2885 please respond ASAP. Outside of bldg 139 POC at bldg 423
115152	7/25/01	AC	Leak coming from the ceiling in the stairway to the left after coming through the main lobby. (don't know if it is a roof leak, pipe leak or an AC leak) investigate and determine the cause of the leak. Repair if within ability to do so.
115169	7/25/01	AC	Clean all air handlers with pressure wash and change belts and filters as required. POC to be contacted before and after work.
115170	7/25/01	AC	Stand won't go cold/work stop
115194	7/25/01	AC	Test stand too hot work stop
115212	7/25/01	AC	Water in air compressor head.
115218	25-Jul-01	Ventilation	Blower motor in exhaust duct has quit working. Now have only one exhaust duct functioning.
115219	7/25/01	AC	Check AC in new area of pneumatics that is used by shop 94403
115221	7/25/01	AC	Ice machine is down, pump was removed from drain pan. What is its' status??????
115228	7/25/01	AC	Not cooling glues and adhesives are not working properly work stoppage
115230	7/26/01	AC	Shop 96332 has no AC. It is 90 degrees in this shop.
115256	7/26/01	AC	The AC upstairs in bldg 200 is not working properly. In certain areas it is very warm. The temperature thermometer on the wall says 84 degrees.
115273	26-Jul-01	Ventilation	Repair exhaust fan in varsol still room. Attn. NADEP electrician. Parts on order.
115294	7/26/01	AC	Ref ticket 113571. AC leaking water onto electrical storage unit again. Got a mess going on downstairs. Need help ASAP. Thanks (113915 is still open on this job)
115301	7/26/01	AC	Secure the fan in Mezzanine B for the front office, and on Friday at 3:30 PM, monitor pipefitters doing work, and when they are done, turn the unit back on. AC mechanics
115304	7/26/01	AC	Still warm in shop. Second call. Ref: ticket 114915.
115335	7/26/01	AC	Check oil level in Trane compressors and record readings each day. 6.3.658
115336	7/26/01	AC	Check operation of chillers and record readings each day. 6.3.658
115337	7/26/01	AC	Check operation of chillers and record readings each day. 6.3.658
115338	7/26/01	AC	Check operation of chillers and record readings each day. 6.3.658
115339	7/26/01	AC	Check operation of chillers and record readings each day. 6.3.658
115351	7/27/01	AC	Water leak in blade room
115373	7/27/01	AC	AC ducts in pc office are leaking condensation (water) on computer equipment.
115382	27-Jul-01	Ventilation	Repair exhaust fan in varsol still room. Attn. NADEP electricians. Parts on order.
115383	7/27/01	AC	The AC in test cell #6 is inoperable. We are currently operating this test cell. We need this fixed as soon as possible. Thank you

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
115385	7/27/01	AC	Need a status on the AC problem in the landing gear shop on the Mezzanine. The unit seems to be blowing warm air. Thank you. (AC problem is being worked on. #114663 & #114908 related)
115386	7/27/01	Vents	Vent pipe damaged for exhaust fan
115396	7/27/01	Vents	Exhaust fans install belts need adjustment.
115398	7/27/01	AC	AC is making noises, 1st ticket# 113139 on 6-29 nobody has showed up.
115412	7/27/01	Vents	AC return vent needs cleaned. The holes in the grill are clogged with dust and dirt. Not much air coming through. 940 SBU office right across from the supervisors office.
115414	27-Jul-01	Ventilation	Ventilation for welding shop not working properly. The motor on roof needs to be looked at to determine the problem, not enough suction
115427	7/27/01	AC	The temp in this office stays at 80 to 82 degrees constantly. There is very little airflow coming into the vent in the overhead. There are several constriction areas just above this office. See me for details. Thank you.
115429	7/28/01	AC	Ceiling light has water leaking from it to the floor. Light is in the HDSC in the 940 area. That will be your POC. Please assist. Thank you.
115436	7/30/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
115450	7/30/01	Vents	Please replace bearing in exhaust vent no. 17.
115459	7/30/01	AC	Facility AC is down please repair
115462	7/30/01	AC	Please adjust air vent in office (2nd floor - training). Does not blow at all. Thanks!
115465	7/30/01	AC	1st ticket# 111234 nobody has showed up!!! Drain on AC is stopped up, water is every where
115472	7/30/01	AC	Water is leaking through the exhaust vent of our shop's paint booth. This type of leak has previously caused the electrical motor to have to be replaced. Request repair as soon as possible. Sent 7/30/01 at 0940.
115505	7/30/01	AC	Repair conference room AC as per instructions.
115506	7/30/01	AC	Repair hot water problem in the equipment room
115507	7/30/01	AC	Repair controls and compressor in the Mezzanine B front office AC
115509	7/30/01	AC	Investigate AC problem with contractor mechanical services. Determine cause and make report.
115515	7/30/01	AC	During previous maintenance being performed the contractors have failed to replace ceiling tiles in the lab/upstairs office and removed a sprinkler head ring off. Please replace per fire marshal. Currently there are wet tiles in the upstairs office area.
115521	7/30/01	AC	AC has quit. We are hot. Located behind old 950 division office.
115539	7/30/01	AC	Cooling unit for tank-033 is not working properly thanks
115557	7/31/01	Vents	It is requested that the vents at work area 10CL (paint shop) be checked as they are blowing hot air.
115559	7/31/01	AC	Repair conference room AC as per instructions.
115561	7/31/01	AC	Compressor short cycling repair

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
115565	7/31/01	AC	Clean coils in air handlers in bldg 4032
115566	7/31/01	AC	Office temp hovers around 66 degrees. Need to have the vent in this small office adjusted closed.
115574	7/31/01	AC	AC filters & screens in office need to be cleaned. Mezzanine in h46 hangar. Bldg 137, hangar 3.
115575	7/31/01	AC	Water leaking through ceiling. Water has pooled inside light fixture. I am located in the hazmat room within the 94400 division in the front of bldg 137
115598	7/31/01	AC	Mezzanine C 941 SBU AC in office is blowing warm air. Had to open the door to let air in.
115622	7/31/01	Vents	Vent 137-v297 is vibrating excessively on the roof; roof was vibrating.
115626	7/31/01	AC	Request AC be adjusted to around 70 degrees shop temp is staying at 65 degrees. Sent 7/31/01 at 1300.
115642	7/31/01	AC	Clean around the chillers in the bldg 133 equipment room
115643	7/31/01	AC	Repair wotan chiller and insulate piping
115644	7/31/01	Vents	Replace bearings on the vent 23 as per instructions attn: D&J electric
115645	7/31/01	AC	Repair/replace tev valve in the test stand as per instructions
115652	7/31/01	AC	System does not cool or remove humidity effectively.
115658	31-Jul-01	Ventilation	Vent in E-2 rubber room will not come on work stoppage.
115699	8/1/01	AC	Repair AC in vibration analysis shop. 2nd floor. See before doing the job.
115700	8/1/01	AC	May need to move thermostat. Cold air from vents blowing directly on the thermostat.
115704	8/1/01	AC	There is evidence of something leaking above the ceiling in computer labs rooms 111 and 112. Ceiling tiles are stained and bowed Leaks in these rooms could cause extensive and highly costly damage to computer equipment and also lead to a work stoppage.
115713	8/1/01	AC	Alarm on AC unit. Humidity alarm. Telephone room, Mezzanine B.
115728	8/1/01	AC	Perform operational test on the York chiller bldg 133
115729	8/1/01	AC	Drain and refill hot water system in bldg 4224 for contractor, report when complete
115730	8/1/01	AC	Check out the pneumatic controls in the front office area for the co's office.
115731	8/1/01	AC	Check and repair controls in the cable shop bldg 137 Mezzanine D.
115733	8/1/01	AC	Repair compressor as per instruction Mezzanine B
115748	8/1/01	AC	Repair leak in roof and replace damaged ceiling tiles in SSE area
115749	8/1/01	AC	Replace EPD1H-BB40 differential switch on the hot water pump 4224
115750	8/1/01	AC	Repair control air compressor Mezzanine B attn tri-plex
115767	8/1/01	AC	Shop AC inoperable. Temp in shop is 82 degrees F
115776	8/1/01	Vents	The expansion joints on the exhaust vents needs replacing. Thanks

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
115781	8/1/01	AC	Install a thermostat in suite 62 for the AC or move the thermostat for AC from suite 63 to suite 62
115782	8/1/01	AC	Mezzanine E. Computer shop, AC unit not working. Could be the belt, problems with this before. Climate controlled area. Will be work stoppage.
115788	8/1/01	AC	Area hot by sanding pit.
115810	8/2/01	AC	#1 T64 mech stand T2 is malfunctioning. Work stop
115837	8/2/01	AC	Retro fit test stand # 65923003682-T-58
115841	8/2/01	Vents	The expansion joints on the exhaust vents needs replacing. Thanks
115862	8/2/01	AC	Ceiling leak in room 871. Water actually coming through the ceiling and onto the floor.
115868	8/2/01	AC	Repair AC unit in telephone equipment room Mezzanine B
115892	8/2/01	AC	Check oil level in Trane compressors and record readings each day 6.3.658
115893	8/2/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
115894	8/2/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
115895	8/2/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
115896	8/2/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
115905	8/3/01	AC	Leak in roof, ceiling tiles are falling down, water all over his desk. All the papers on his desk are ruined. Repair leak and replace damaged tiles.
115937	8/3/01	AC	It appears that the repair of the 960 SBU AC has been completed. However, only half of the system was turned back on. Would you have them restore the other half?
115945	8/3/01	AC	Fan motor on the AC unit is broken.
115954	8/3/01	AC	#1 T64 mech stand T2 is malfunctioning. Work stop
115958	8/3/01	AC	Repair T-2 probe in test cell #3 (shop code 6.52)
115960	8/3/01	AC	Check air handler #3 for water leak.
115966	8/3/01	AC	Remove refrigerant and dispose of.
115995	8/4/01	AC	Leaking water and making a loud squealing sound. (I don't know if this is a piece of equipment or not, there is no EIN though.)
115996	8/6/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
115997	8/6/01	AC	Request immediate maintenance of AC services to bldg 200. Appears as though air was shut off completely over the weekend or there is an equipment problem. Conditions in bldg are extremely uncomfortable.
116001	8/6/01	AC	Leak coming from AC unit. Room 871
116003	8/6/01	AC	Repair refrigerant leak number 1 compressor
116004	8/6/01	AC	Repair AC in the Mezzanine in the machine shop



Ticket Number	Date	Problem Type	Description
116008	8/6/01	AC	AC in the new annex area in the rear of the bldg does not come on until around 9:00 am. Could the thermostat be adjusted so it comes on sooner? The people are sweating every morning due to the heat.
116014	8/6/01	AC	Test stand chill water lines not wrapped, condensation is causing water puddle in floor and benches request attn. This a safety hazard.
116015	8/6/01	AC	Chillers for the process tanks are not working, work stoppage. Thanks
116017	8/6/01	AC	Repair refrigerant leak number 1 compressor
116034	8/6/01	AC	Urgent request to have someone come over and reset the AC in the Sermetel room this is a work stoppage request. We need this done ASAP thank you...
116056	8/6/01	AC	Refill hot water system in the 4224 bldg
116058	8/6/01	AC	AC in the old rubber shop is too cold.
116062	8/6/01	Vents	W-25 ladies room. Return vent needs cleaned.
116065	8/6/01	AC	Coil froze on condenser please check unit. May be warranty
116072	8/6/01	AC	AC doesn't cool properly. I.E. set at 72 temp 77. Need regulated temp and humidity for proper use of adhesives
116074	8/6/01	AC	Cold water line above dip tank in rework shop is leaking water, causing slip hazard.
116077	8/6/01	AC	Remove thermostat controls from old blasting room. Terminate back to source.
116078	8/6/01	AC	Repair small hot water converter. Do not shut steam off with out pre-approval. Send to contractor
116079	8/6/01	AC	Check leak on Mezzanine B, water coming from under wall
116091	8/6/01	AC	Need refrigerant leak repaired on the Sermetel AC in penthouse 3 133. NADEP tied up on other equipment. Work stoppage
116102	8/6/01	AC	Water leaking from ceiling by post-test area. Suspect it is coming from AC overhead. In P-507 test cell.
116104	8/6/01	AC	AC in the rubber shop isn't working to its full capacity, hindering operations when using adhesives.
116109	8/6/01	AC	Clean room AC inoperable and humidity is extremely high. Water is dripping on tables and floor. Work stoppage.
116111	8/6/01	AC	Chill water inoperable on ASE test stand # 4. Work stoppage.
116145	8/7/01	AC	I am really not sure the source of the problem. There is a leak coming from the ceiling onto the strip tank in small cleaning area. This is a work stoppage. We cannot use large strip tank due to leakage of water. POC is supervisor 93111c.
116157	8/7/01	AC	Repair AC # 3
116173	8/7/01	AC	As requested we are trying to reach about the AC upstairs. Unit is running but will not cool area. He told us if it does not work to contact him and he would try other methods. Lowering duct work in shop?
116176	8/7/01	AC	AC is not working in the lab portion of the bldg there is an error message of "E-2" if that is any help.
116183	8/7/01	AC	Repair AC in shop

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
116194	8/7/01	AC	Repair bad fan motor in penthouse #3
116201	8/7/01	AC	AC is out in H53 main gearbox area, a lot of high dollar parts and assemblies.
116205	8/7/01	AC	Shop 96332 AC is out again. (this may be an area that is under the load shed that is in effect)
116210	8/7/01	AC	AC in 4 & 5 test cell inoperable.
116221	8/7/01	vents	Paint booth is not ventilating properly.
116231	8/8/01	AC	AC not working -- its 0610 and its 82 degrees in the bldg
116237	8/8/01	AC	It is requested that ice machine 65923049566 located in break room of this bldg, be repaired as it is not working.
116258	8/8/01	AC	No AC. Hot
116265	8/8/01	AC	Repair air dryer as per instructions
116277	8/8/01	AC	Repair 1 1/2 copper pipe joints, re solder
116289	8/8/01	AC	Repair LP gas line at bottle and replace regulator and all damaged pipe to bldg stabilize tank, see before starting to work
116297	8/8/01	AC	T2 air inoperable
116301	8/8/01	AC	AC too cold. Please adjust.
116305	8/8/01	AC	AC too cold?
116313	8/8/01	AC	High humidity in clean room please repair.
116324	8-Aug-01	Ventilation	The main control panel for vent motors d106/663-666 does not work. The panel is located in the old paint hangar on the west side of the bldg
116327	8/8/01	Vents	Lubricate vents
116345	8/9/01	AC	There is no AC in all of bldg 4224.
116346	8/9/01	AC	Please check to see if AC broke after load shedding yesterday. It is 85+ in the office at 0630 today.
116349	8/9/01	AC	No AC in mixing room work stoppage
116376	8/9/01	AC	Both AC's in shop 93552, located in the ramp bldg in 137 aren't blowing cold air at all. Repairmen worked on them last week and said that they were fixed. They have been messing up again since Monday afternoon.
116379	8/9/01	AC	AC is out in the plasma spray room. Says it has been out about a week, but I couldn't find any other ticket on this area.
116393	8/9/01	Vents	Fix exhaust fan in can 1380.
116400	8/9/01	AC	Air handler #12 is off line and has been verified it is not in load shed. (I don't know if this has any relationship to the AC being off in the plasma room, ticket #)
116418	8/9/01	AC	Upstairs in the annex, air coming from vents, but it is not cold.
116421	8/9/01	AC	Not sure if it is AC, but water is all over the floor, and appears to be oozing out of the wall!

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
116427	8/9/01	AC	HVAC unit leaks water when it rains in plasma spray room, bldg 4225. Seal HVAC unit so it is watertight. May need the "door seals" replaced. This job needs done before the ceiling tiles can be replaced.
116432	8/9/01	AC	Reclaim refrigerant and dispose of properly.
116440	8/9/01	AC	Repair air distribution in office area
116445	8/9/01	AC	Test cell #3, control room AC is down.
116446	8/9/01	AC	Repair several steam coils in new section of bldg 245 ASAP. Contact for particulars on this situation.
116447	8/9/01	AC	Repair controls in the 4224 bldg
116463	8/9/01	AC	Check oil level in Trane compressors and record readings each day. 6.3.658
116464	8/9/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
116465	8/9/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
116466	8/9/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
116467	8/9/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
116481	8/10/01	AC	Freon needed service in test stand
116484	8/10/01	AC	There is no AC in Mezzanine B.
116495	8/10/01	AC	Chilled water for bldg 4225 is 62 degrees F.
116496	8/10/01	AC	AC unit in bldg 1377 is not functioning. This unit is vital for the storage of photographic film. Please repair ASAP. Thanks
116505	8/10/01	AC	Replace bad safety switch on AC
116515	8/10/01	AC	AC in men's room is not cooling. Please check.
116523	8/10/01	AC	AC appears not to be working. Office temp 80+ degrees. Men's restroom and the machine shop are significantly cooler. This is not due to load share.
116525	8/10/01	AC	Clean the AC vents, odor in area.
116530	8/10/01	AC	The temp and hum is out of whack in the clean room - work stop - need repair ASAP.
116536	8/10/01	AC	Replace bad compressor on AC for shop.
116564	8/10/01	AC	Water leaking from ceiling in ARBS room. Possibly AC
116570	8/10/01	AC	Bldg 4225 second floor computer room AC has set point of 70f and is currently 79f and rising.
116573	8/10/01	AC	Water leaking through ceiling tiles in the front of the shop. It has leaked here before.
116579	8/10/01	AC	Repair vent over Kertsite oven in heat treat
116580	8/10/01	Vents	Exhaust fan over melting pot in foundry area is not working. They have men working tonight and this weekend. Work stoppage

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
116588	8/11/01	AC	Repair refrigerant leak in the Trane compressor in the basement of 4035. This is a critical repair. Tri-plex was working on this and has not finished.
116590	8/11/01	AC	Replace shaft on the air handler in penthouse number 10, ASAP. Old one rung off.
116591	8/11/01	AC	Repair, replace the steam valves in the penthouse 12. See me before work begins.
116592	8/11/01	AC	Install "P" traps on all of the air handlers to the 133 penthouses as per instructions. ASAP. Some leaking in the air handlers.
116593	8/11/01	AC	Repair hot water controller in bldg 4224 as per instructions
116595	8/11/01	AC	Fill hot water systems in bldg 4224
116596	8/11/01	AC	Repair controls in the cable shop as per instructions
116597	8/11/01	Vents	Exhaust vents in E-2 rubber room is not working work stoppage.
116598	8/11/01	Vents	Exhaust vent in P-3 lead remover room is not working work stoppage.
116600	8/13/01	AC	Repair air dryer in the front equipment room ASAP water damaging the pneumatic controls .
116601	8/13/01	AC	Please check AC for upstairs/rear of bldg 4224. It is already 84 degrees in here.
116616	8/13/01	AC	Office has a leak in the ceiling. Last time it was the AC
116618	8/13/01	AC	HVAC unit that services the hygiene addition in bldg 4225 is leaking water. May be a warranty issue.
116620	8/13/01	AC	T-64 test stand mech #1 the T-2 not cooling down. Work stoppage.
116622	8/13/01	AC	Repair conference room AC co area. Possible problem is covered by warranty.
116626	8/13/01	AC	Freon needed in T -58 test stand
116628	8/13/01	AC	Water leak from unit into office area
116629	8/13/01	AC	Chilled water pipes are leaking behind test stand. 4 & 5 test cell
116632	8/13/01	AC	AC needs repairs.
116636	8/13/01	AC	Chiller off, restart.
116652	8/13/01	AC	The AC had started to work but now it is getting warmer again. Please check out the handler. Upstairs/rear of bldg
116654	8/13/01	AC	Chiller is not cooling.
116655	8/13/01	Vents	Replace bearings in vent 4035-24
116662	8/13/01	AC	T2 won't go cold.
116664	8/13/01	AC	Check chillers every morning for operation.
116673	8/13/01	AC	Replace bearing in the air handler on the roof of 4224. Work stoppage
116675	8/13/01	AC	Repair AC in the bldg shop area ASAP
116676	8/13/01	AC	Repair AC as per instructions
116678	8/13/01	AC	Water dripping from ceiling. Slip hazard. Bldg 137, hangar 3, H46 E&E office.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
116697	8/13/01	AC	Calibration lab, climate controlled area no AC
116703	8/13/01	AC	Please fill up hot water system.
116728	8/13/01	AC	Heat detectors need repair. Fire marshal write-up. Please assist ASAP. Thanks
116736	8/13/01	AC	Water leaking from AC unit on roof at work station #5 large stackers. This leak is continuous and wets boxes and parts. It is directly over pallet work area of the rollers.
116739	8/14/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
116750	8/14/01	AC	Load shedding shouldn't be in effect at night, other AC's are working, AC is putting out air that is partially cooler than any air it's taking in, QA had same problem last week, it was hot up here last night. 6.1.535 h46 E&E
116751	8/14/01	AC	Provide an 8500 BTU window AC unit in the hooch in the H-53 hangar. Window will need to be removed and framed in to accommodate.
116752	8/14/01	AC	Have leak in main doorway. Water is in light fixture directly above computer. Am located in the front of 137 within the 94400 division, HDSC 137C – hazmat
116769	8/14/01	AC	Excessive water leak over top of light in mixing room.
116785	8/14/01	AC	Room 172, workman's comp. Office. Bad leak coming through the ceiling.
116786	8/14/01	Vents	Stop leak that is coming in by way of the heater vent in rear of can 1381.
116794	8/14/01	AC	Manufacture adapters for York chillers.
116797	8/14/01	AC	AC out in H53 MGB build up area, lots of hi dollar parts already built up
116804	8/14/01	AC	Exhaust vent leaking through roof in Mezzanine F shop area, approx. 1/2 way down Mezzanine F
116806	8/14/01	AC	Temp has increased by approximately 6 degrees in the last hour. I was told you are not load shedding, so unit must be out of order. Please investigate.
116807	8/14/01	vents	Louvers on the 0H3 scrubber in the plating shop is malfunctioning
116809	8/14/01	AC	Replace filters and clean coil on units
116820	8/14/01	AC	AC is out in H53 MGB area-----2nd call
116821	8/14/01	AC	T2 will not go hot work stoppage
116847	8/14/01	AC	AC in gage room will not keep room within limits.
116849	8/14/01	AC	Air or chill water lines are noisy above dowty test stand.
116862	8/15/01	AC	The alarm keeps going off on the AC, no light is showing up but when you hit the silence it shuts off. Need someone to check it out. Located computer room Mezzanine 9.
116871	8/15/01	AC	T2 won't go hot. Work stop T58-#5
116874	8/15/01	AC	T2 takes a long time to go back to 75 from 145/T58 #1.
116894	8/15/01	Vents	Vent system not working in mechanical rooms upstairs and downstairs

Ticket Number	Date	Problem Type	Description
116903	8/15/01	AC	No AC all week it is over 83 degrees in here again today
116906	8/15/01	AC	T2 will not go hot. Work stoppage
116910	8/15/01	AC	Install chill water coil per instructions (coil to be installed)
116912	8/15/01	AC	The AC in the shop is not working, please repair.
116917	8/15/01	AC	T2 on ASE stand won't go hot/work stop
116938	8/15/01	Vents	Belts on upper exhaust motors in stall no 3 appear to be loose. Need tightening to increase vapor exhaust in old hanger.
116942	15-Aug-01	Ventilation	Exhaust fan in head by test cell # 3 is inoperable.
116954	8/15/01	Vents	Ventilation in dispensing room is inoperable. Repair ASAP. Employees are affected by the vapors and is a safety issue. Refer to closed ticket #102248, #102840.
116966	8/15/01	AC	Repair AC per instructions
116997	8/16/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
117021	8/16/01	AC	T-64 mech #1 the T-2 not cooling & not blowing air. Work stoppage
117022	8/16/01	AC	T-64 mech #2 test stand the T-2 won't hold 69 degrees. Work stoppage
117023	8/16/01	AC	T2 inoperable
117029	8/16/01	AC	Check the chill water system, it is not cooling and there is no pressure.
117031	8/16/01	AC	2nd floor - training branch. Air vent needs to be adjusted to keep from blowing directly. Thank you!
117051	8/16/01	AC	AC has quit working again. It was 76 and cool this morning, but temp is now approaching 80.
117066	8/16/01	AC	AC and humidity controls are inoperable for the clean room in bldg 4224. This is a work stoppage. Please repair ASAP
117124	8/16/01	AC	AC in 402 test cell control room not cooling, temp in control room @ 82 degrees work stoppage
117126	8/16/01	AC	Check oil level in Trane compressors and record readings each day. 6.3.658
117127	8/16/01	AC	Check operation of chillers. Take and record readings each day. 6.3.658
117128	8/16/01	AC	AC leaking water on ASKAR work station 05 kitting. This leak is damaging parts located on pallets at this work station
117129	8/16/01	AC	Check operation of chillers. Take and record readings each day. 6.3.658
117130	8/16/01	AC	Check operation of chillers. Take and record readings each day. 6.3.658
117131	8/16/01	AC	Check operation of chillers. Take and record readings each day. 6.3.658
117148	8/17/01	AC	AC problems on Mezzanine F. Calibration lab, there seem to be a steam problem 61 degrees in shop area, calibration work stoppage.
117151	8/17/01	AC	Add 50 percent solution of antifreeze to fill tank for cooling tower at bldg 139.
117199	8/17/01	AC	Hot in shop.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
117201	8/17/01	AC	Fine tune hot water system.
117207	8/17/01	AC	Roof top heat pump 8-1 bldg 159 filter in alarm status change filters in RTHP 8-1, 8-2, 8-2, 8-4 and IHP 8-1
117210	8/17/01	AC	Check out the AC. It is getting quite warm up there. Could be load shedding, could not be.
117213	8/17/01	AC	Change filters on heat pumps in upstairs office area. These two units are carrier package units. Install HEPA type filters if possible.
117254	8/18/01	AC	AC water leak at LIS #5 work station ASKAR kitting material section
117268	8/20/01	AC	T2 inoperable on T64 mech 1 stand. POC: john cross work stop
117269	8/20/01	AC	T2 inoperable on the T64 mech 2 test stand. Work stop
117271	8/20/01	AC	T58 mech 1 stand is not getting to -25 and takes forever to get to 145 degrees seems like there is no airflow.
117275	8/20/01	AC	AC system is down.
117294	8/20/01	AC	AC unit in loft area dead again. Need relief. Closed area.
117298	8/20/01	AC	Water leaking from overhead to floor in accy test area above T64 mech #1 test stand
117315	8/20/01	AC	Coils keep freezing, suspect water in air dryer
117338	8/20/01	AC	Check the chill water system, it is not cooling and there is no pressure.
117345	8/20/01	AC	T2 won't reach 145 degrees/work stop
117346	8/20/01	AC	No AC in rear right corner of accy test area - rest of test area AC working fine.
117353	8/20/01	AC	T2 systems freezing-up on ASE test stands indicating that desiccant requires changing in shop air dryers.
117366	8/20/01	AC	The alarm keeps going off on the front AC. No light is showing but when you hit the silence it shuts off. Need someone to check it out tonight. Located in computer room Mezzanine G.
117374	8/21/01	AC	The hum in clean room 85%. Work stop. Bearings sweating. Will lose bearings to corrosion. Correct ASAP.
117390	8/21/01	AC	AC in computer room shut down. AC is started back up, but alarms are going off.
117403	8/21/01	AC	Relocate return grill in shop 659 over 24" to make room for new office.
117426	21-Aug-01	Ventilation	Exhaust fan not currently working on penetrant line at station 8. Unable to draw steam out and fogs up workers glasses. Please check and repair.
117443	8/21/01	AC	AC is not working in H53 MGB test cell control rm. Alarm light is on. Lots of electrons in room.
117460	8/21/01	AC	Tube is off the thermostat that connects to the chill water system in the tool room.
117467	8/21/01	AC	Test stand will not reach temp work stoppage
117469	8/21/01	AC	Test stand T2 will not reach temp work stoppage
117471	8/21/01	AC	AC out in the section near the windows. It hasn't been on in approximately 2 hours. Please investigate.
117480	8/21/01	AC	Water leak from chilled water unit above computer console

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
117492	8/21/01	AC	AC is not working, thermostat is set at 70. Temperature is above 80. Above ASKARS area on the second deck.
117505	8/21/01	AC	Ceiling leak in H-46 drive systems area over a printer. Could be AC or roof, they cannot really tell.
117541	8/22/01	AC	Check bearing shop every morning.
117542	8/22/01	AC	Check chillers every morning.
117545	8/22/01	AC	Test stand won't go to 145 degrees/work stop
117555	8/22/01	AC	Water leak from cooling unit in the electrical room shock hazard safety notified
117568	8/22/01	AC	AC condensate leak in the SBU office near a sprinkler head. (FMD originally sent to check out). Please notify when repairs done because ceiling tiles around sprinkler will need replacing.
117575	8/22/01	Vents	Repair rubber boot on scrubber exhaust
117583	8/22/01	AC	Repair refrigerator already completed
117585	8/22/01	AC	Assist installation of chill water coils
117592	8/22/01	AC	Stroke steam valve to steam converter
117616	8/22/01	AC	AC is not keeping bldg cool yet system seems to be on.
117624	8/22/01	AC	AC unit has slight leak on floor.
117625	8/22/01	AC	AC is not cooling properly. Ref ticket # 116750. 6.1.535, h46 E&E office, hangar 3.
117670	8/22/01	AC	F402 test cell control room is excessively hot.
117671	8/23/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
117681	8/23/01	AC	Water leaking from the roof/ceiling causing a safety hazard, need fixing before someone slips and get injured. This problem has been called in for repair several times. Location is in the PC area.
117716	8/23/01	AC	Water knife overheating.
117726	8/23/01	AC	No chill water available for water jet. Investigate please
117734	8/23/01	Vents	Repair rubber boot on scrubber exhaust
117744	8/23/01	AC	Fumes coming into area through AC vents, smells like exhaust fumes.
117752	8/23/01	AC	Power outage in whole bldg cause HVAC to not cool need chiller turn back on.
117767	8/24/01	AC	Repair refrigerated air dryer in the air compressor room, work stoppage. See me before starting work
117773	8/24/01	AC	Welding school, water heating up in the welding torches. Check chill water and pump for chill water. Work stoppage. Torches are getting too hot.
117826	8/24/01	AC	Request that a leak in the shop be repaired, water leaking in top of machining fixtures.
117845	8/24/01	AC	(Front of 4033) office is extremely hot and right outside of his office is cold. Need to have the registers checked in his office or possible have some relocated.
117854	8/24/01	AC	Replace AC filter in ATB office



Ticket Number	Date	Problem Type	Description
117859	8/24/01	AC	Sermetel AC doesn't seem to be cooling very well. Please check it out.
117862	8/24/01	AC	Check oil level in Trane compressors and record readings each day
117863	8/24/01	AC	Check operation of chillers second shift take readings and record readings each day
117864	8/24/01	AC	Check operation of chillers second shift take readings and record readings each day
117865	8/24/01	AC	Check operation of chillers second shift take readings and record readings each day
117866	8/24/01	AC	Check operation of chillers second shift take readings and record readings each day
117884	8/27/01	AC	Appears that central AC controller was shut off during the weekend. Request that AC be restored to normal status as soon as possible. Currently an uncomfortable 82 degrees in bldg
117885	8/27/01	AC	Assist engineering in balancing or repair of unit in computer room
117886	8/27/01	AC	Over 90 degrees in office area, no AC at all.
117887	8/27/01	AC	Extremely cold in shop...about 60 degrees. Please mix a little heat with the cold.
117888	8/27/01	AC	AC unit in his office next to the lobby is leaking. The leak has destroyed a printer over the weekend. Could be a clogged drain.
117892	8/27/01	AC	It's 84 in 4188 upstairs. I think our AC is broken.
117899	8/27/01	AC	80 degrees plus in computer control room, please expedite repair
117900	8/27/01	AC	80 degrees plus in computer control room, please expedite repair - f402 test cell
117906	8/27/01	AC	Repair air flow problem in XO's office
117907	8/27/01	AC	Relocate thermostat per instructions.
117908	8/27/01	AC	Replace pneumatic controls on AC as per instructions.
117909	8/27/01	AC	Repair oil leak on 100-ton compressor, Mezzanine B, warranty item
117910	8/27/01	AC	PM and clean air handler.
117911	8/27/01	AC	Thermostat in T-26 test cell does not appear to be working. Please fix.
117916	8/27/01	AC	CRU #3 (Liebert) in computer lab room 112, has developed a bad vibration which could lead to failure.
117929	8/27/01	AC	Chiller not working on anodize line.
117935	8/27/01	AC	AC is not working in the training room area.
117936	8/27/01	AC	Check AC every morning.
117937	8/27/01	AC	Check chillers every morning.
117960	8/27/01	AC	Check AC every morning.
117978	8/27/01	AC	AC not working within the 96000 training room/office area in bldg 133. Request this system be checked. Classes/meetings cannot be conducted until the AC is fixed (work stoppage). Thanks.
118006	8/27/01	AC	The alarm keep going off and on front AC Mezzanine G in computer room.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
118010	8/27/01	AC	AC outside the high voltage doors next to the ramp bldg, oil level is low on one of the compressors
118038	8/28/01	AC	Water dripping down from pipes onto floor/safety issue
118046	8/28/01	AC	AC not working in the clean room.
118058	8/28/01	Vents	Safety/ exhaust vent in strip barn will not function/ please repair ASAP
118059	8/28/01	AC	Refrigerant air dryer for plant air inoperable.
118076	8/28/01	AC	Request that thermostat be turned down on chill water for fleet training welding school. Please expedite
118077	8/28/01	AC	Repair and inspect total unit for proper operation in bldg make necessary adjustments for proper airflow
118087	8/28/01	AC	Freon had to be replaced about 1 month ago and I think it needs it again. Air set on 70 but it is 77-79 degrees. Thank you this is AC that is in front part of shop. Supervisors area
118101	8/28/01	AC	Cannot reach T2 cold temp of - 25% even with dry ice
118113	8/28/01	AC	Code 6.2.960 division secretary has indicated the temperature in their office is in excess of 85 degrees F and has been that way all day, 8/27/01. Please issue a work order to have this AC unit checked.
118118	8/28/01	AC	AC on top of ramp bldg is not working and area is over 85 degrees, this is causing problems with CNC machine operation.
118131	8/28/01	AC	Air handler unit on roof over 93562 machine shop not working. AHU4, column G24
118132	8/28/01	AC	Air handler unit on roof over machine shop 93562 not working. AHU2, column E24
118133	8/28/01	AC	Air handler unit on roof over machine shop 93562 not working. AHU4, column G24. Please send to day shift repair unit.
118134	8/28/01	AC	Air handler unit on roof over machine shop 93562 not working. AHU2, column E24. Please send to day shift repair unit.
118136	8/29/01	AC	AC pipes leaking in overhead really bad.
118142	8/29/01	AC	Please check air dryers for the air compressors, there is water in the airlines.
118165	8/29/01	AC	Test stand won't go cold. Work stop.
118186	8/29/01	AC	Secure heat to conference room.
118207	8/29/01	AC	The steam was turned on to check for leaks. No leaks were found but the heat is still running. All which were involved is gone. It is getting very hot. Please have someone come and get the AC back on. Thanks
118216	8/29/01	AC	No steam to run clean room. Is it turned off to work on AC? I couldn't find anything on this area that is open.
118226	8/29/01	Vents	Two make up air units over the nickel plate lines are not working. Thanks
118232	8/29/01	AC	Air handler unit on roof over 93562 machine shop not working. AHU4, column G24
118233	8/29/01	AC	Air handler unit on roof over machine shop 93562 not working. AHU2, column #24
118234	8/29/01	AC	Temp 82 plus in test cell computer room - please expedite

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
118262	8/29/01	Vents	The exhaust fan is not operational.
118268	8/29/01	AC	T2 system inoperable on T64 # 1 manual test stand. Work stoppage
118272	8/30/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
118274	8/30/01	AC	Shop 96332 has no AC. Our shop is upstairs and it get 80 to 90 degrees. Need air check out
118292	8/30/01	Vents	Exhaust fan in head by test cell #1 inoperable. GMS (#117977 could be a duplicate, this ticket covers 3 exhaust fans)
118294	30-Aug-01	Ventilation	Exhaust fan in head by #3 test cell inoperable.
118296	8/30/01	AC	Need the AC carrier in room # 644 of bldg 4032 fixed. There is a piece of metal hanging down that could fall and hit someone.
118320	8/30/01	AC	Repair air dryer in the 377-ton equipment room. Work stoppage.
118325	8/30/01	AC	Replace air filters and belts as required on air handlers on top of the roof.
118370	8/30/01	AC	Assist York contractors as necessary
118381	8/30/01	AC	Mezzanine A, office area, odor. Please check it out and fix if possible.
118407	8/31/01	AC	AC has not been working for two days in the admin office, hallways and six classrooms. (ticket # 116072 is still open on this grid area, this could be a duplicate)
118424	8/31/01	AC	Chilled water system inoperable.
118451	8/31/01	vents	Scrubber a-oh-4 is not working, work stoppage. Will not restart. Thanks
118472	8/31/01	AC	Liebert, AC in the L&M room is inoperable
118478	8/31/01	AC	Restart chill water systems.
118479	8/31/01	AC	T2 won't maintain 69 degrees/work stop andrews-T64 #1 mechanical
118483	8/31/01	AC	No AC in mixing room work stoppage
118488	8/31/01	AC	Ceiling leak in H-46 drive systems area over a printer. AC pipe insulation dripping. Please check/repair ASAP.
118496	8/31/01	AC	Check oil level in Trane compressors and record readings each day 6.3.658
118497	8/31/01	AC	Check operation of chillers second shift. Take and record readings each day. 6.3.658
118498	8/31/01	AC	Check operation of chillers second shift. Take and record readings each day. 6.3.658
118499	8/31/01	AC	Check operation of chillers second shift. Take and record readings each day. 6.3.658
118500	8/31/01	AC	Check operation of chillers second shift. Take and record readings each day. 6.3.658
118514	9/2/01	vents	Blowers in paint stall # 4 won't come on. Help
118515	9/2/01	AC	T58 fuel control test stand has no chilled water. Work stop! RCA room has no chilled water. Work stop!
118519	9/4/01	AC	No AC in office areas, very hot.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
118523	9/4/01	AC	80 degrees upstairs. He can see ice on the insulated lines and it is dripping.
118524	9/4/01	AC	Very cold in shop. Please add a little heat.
118525	9/4/01	AC	AC is really, really working, the temperature started to drop about 5 am Saturday morning. It is about 65 degrees in the area, it is supposed to be an environmentally controlled area.
118527	9/4/01	AC	(Repeat) AC not working within 96000 training room. Class meetings cannot be conducted without the AC ventilation system working. Please check out. Thanks .
118533	9/4/01	AC	Test stand won't regulate on cold side/work stop T64 mech #1.
118538	9/4/01	AC	Help!!!! Don't know if our AC was turned off for the weekend or not, but if not, we don't have any. Please come check.
118547	9/4/01	AC	AC not functioning in the training facility, bldg 4034. AC units were checked Friday August 31 01, but are still not functioning properly.
118564	9/4/01	AC	Check clean room AC daily
118566	9/4/01	AC	Check chillers daily
118567	9/4/01	AC	Start chillers in basement
118572	9/4/01	AC	AC still not working in office areas. Need help ASAP!
118578	9/4/01	AC	Mezzanine B telephone room drain may be clogged, water coming onto floor, more than just a little condensation.
118581	9/4/01	AC	Filters need changed in AC that services pmc room
118588	9/4/01	AC	The drain in the AC on the roof may be stopped up.
118615	9/4/01	Vents	The vent in the ladies bathroom above the eatery is not working.
118635	9/4/01	AC	T2 system inoperable on T58 manual test stand # 1. Work stoppage
118640	9/4/01	AC	T2 system requires freon on T64 manual test stand # 2.
118645	9/5/01	AC	Thermostat needs checking. Read 80 degrees yesterday. A warm 78 degree reading this morning. Was just fixed and preset at 72 degrees not long ago. We are located in the ASKARS bldg MM store side. Thank you.
118653	9/5/01	AC	The ice machine outside the instrument shop is inoperable.
118674	9/5/01	AC	Replace 32 filters in AC unit
118686	9/5/01	AC	Water leaking from AC duct. Leak is getting steadily worse.
118730	9/5/01	AC	Chillers are down for the anodize process, work stoppage. Thanks
118733	9/5/01	AC	AC not operating, thermostat has filter symbol (clogged filter?), mode is "off" and locked
118738	9/5/01	AC	Humidity too high in the clean room. Work stoppage
118743	9/5/01	AC	Chillers are off.
118745	9/5/01	AC	Water dripping from ceiling through light fixture
118764	9/6/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
118773	9/6/01	AC	Install a small heat pump/AC window unit in wood yard enclosure.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
118781	9/6/01	AC	I'm in the SSE room of bldg 188 with a motorized vent door opener 3 feet above my head making very high pitch noises. It sounds like bearings have gone bad. Started Tuesday for a short time now it never stops. May become a possible fire hazard!
118783	9/6/01	AC	T2 won't hold 75 degrees
118784	9/6/01	Vents	Fan in men's head inoperable need repair
118791	9/6/01	AC	Air dryer, motor bad.
118792	9/6/01	Vents	There is still no ventilation in the ladies bathroom above the eatery. Ref: ticket no 118615
118800	9/6/01	AC	T2 won't go cold work stop T64 mech #2
118810	9/6/01	AC	Unit has blown the plug out of the end of the condenser coil
118812	9/6/01	AC	The AC in the mechanical room on Mezzanine B is leaking. Please repair.
118824	9/6/01	AC	Computer room AC quit working, alarms went of humidity control and airflow.
118827	9/6/01	AC	Replace the filters in unit 00937 & 00936. 64 filters in all
118932	9/7/01	AC	T2 system inoperable T64 mech #1
118939	9/7/01	AC	AC in their shop is not working. Said the unit outside is not working at all.
118975	9/7/01	Vents	Hot check out ventilation system in salt bath area. (D&J)
118989	9/7/01	AC	Check out and take superheat reading on AC, one with new lines. Determine whether expansion valve is bad. E-mail with the results.
118996	9/7/01	AC	Check oil level in Trane compressors and record readings each day 6.3.658
118997	9/7/01	AC	Check operation of chillers second shift, take and record readings each day. 6.3.658
118998	9/7/01	AC	Check operation of chillers second shift, take and record readings each day. 6.3.658
118999	9/7/01	AC	Check operation of chillers second shift, take and record readings each day. 6.3.658
119000	9/7/01	AC	Check operation of chillers second shift, take and record readings each day. 6.3.658
119010	9/8/01	AC	AC unit will not work at all.
119037	9/10/01	AC	Repair refrigerant leaks in the T-64 test stand. May be warranty. See me before doing work. Work stoppage. This is the many times and the machine still leaks refrigerant.
119039	9/10/01	AC	Check balance valve on the condenser pump on number 6 chiller 133
119065	9/10/01	AC	Replace repair fan motor on the air dryer in the 4224 equipment room.
119067	9/10/01	AC	Install replace gaskets, oil pump, capacity controller on the 100 ton compressor front office.
119073	9/10/01	AC	Repair air dryer in the equipment room. Troubleshoot water problem in the blasts booths.
119075	9/10/01	AC	Report on a very annoying, loud, vibration noise in his office. Would it be possible to have someone check it out. Thanks bldg 133 (old 960 office area).

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
119086	9/10/01	AC	Check bearing shop daily
119087	9/10/01	AC	Check chillers daily
119115	9/10/01	AC	AC or other problem, causing 90% humidity in laser room. The high humidity is causing problems keeping the lasers operating.
119139	9/10/01	AC	AC inoperable in hydraulic area.
119170	9/11/01	AC	Clean window AC unit. Filters dirty. QA office.
119171	9/11/01	AC	Change filters in air handler 65923m09711 in back corner of machine shop.
119206	9/11/01	AC	AC has quit and is pumping out heat. Please correct.
119209	9/11/01	AC	Heat now coming out of all AC vents. Extremely warm in shop now. Tomorrow, it will be unbearable. Please fix.
119222	9/13/01	AC	Temp on Mezzanine F electronic calibration lab is 57 degrees, repair as soon as possible, calibration work stoppage.
119225	9/13/01	AC	Drain is malfunctioning/running over.
119231	9/13/01	AC	T2 will not go hot (145) I believe a breaker in the explosion proof box needs resetting
119236	9/13/01	AC	Chill water inoperable on test stand. Work stop. ASE 1.
119237	9/13/01	Vents	PM and repair exhaust vents in vault 2
119241	9/13/01	AC	Start chillers in basement
119243	9/13/01	AC	137 eatery AC is not functioning properly
119248	9/13/01	AC	The temp in our office is only 66 degrees today. Please investigate.
119279	9/13/01	AC	AC leaking on equipment. Equipment is too large to move and will be ruined. Please expedite
119296	13-Sep-01	Ventilation	Spray booth will not operate; exhaust will not operate.
119316	9/13/01	AC	AC is not working - it's 82+ and very humid.
119340	9/14/01	AC	Chill water inoperable work stop
119361	9/14/01	AC	AC is too cold in her office area. Everyone has a coat on. Please turn it up a bit.
119391	9/14/01	AC	T2 won't hold 75 degrees
119408	9/14/01	AC	Please calibrate new thermostat. Thermostat indicates 4 degrees F higher than our thermometer. Thank you.
119422	9/14/01	AC	The heat is back on again, coming out the AC vents. Please turn off the heat, if possible.
119424	9/14/01	AC	AC unit number two leaking water on floor. Suspect clogged drain. Repair as required.
119428	9/14/01	AC	Oven over heating. Work stoppage.
119434	9/14/01	AC	Check oil level in Trane compressors and record readings each day. 6.3.658
119435	9/14/01	AC	Check operation of chillers second shift. Take and record readings each day. 6.3.658
119436	9/14/01	AC	Check operation of chillers second shift. Take and record readings each day. 6.3.658

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
119437	9/14/01	AC	Check operation of chillers second shift. Take and record readings each day. 6.3.658
119438	9/14/01	AC	Check operation of chillers second shift. Take and record readings each day. 6.3.658
119453	9/15/01	AC	Comfort air in heat mode (hydraulic shop - RCA room - annex)
119454	9/15/01	AC	Leaking oil (fluid) on floor near compressor on the wotan.
119459	9/17/01	AC	Temp on Mezzanine F electronic calibration lab is 56 degrees, repair as soon as possible, calibration work stoppage.
119465	9/17/01	AC	Test stand won't go cold. T58 mech #1
119468	9/17/01	AC	It is 66 degrees in here again. Please investigate. (ticket still open)
119479	9/17/01	AC	Condensing unit motor bad, Mezzanine G, computer room area.
119482	9/17/01	AC	Ice machine outside back door of our shop is inoperable. Please repair. Thanks
119487	9/17/01	AC	AC is out. Environmentally controlled.
119525	9/17/01	AC	We have no AC in mixing room work stoppage
119531	9/17/01	AC	AC in main computer room is not working. Called regarding AC.
119532	9/17/01	AC	AC is not running. Temperature and humidity are rising in offices without windows. Please re-start the system.
119542	9/17/01	AC	Linear measurement room temperature and humidity is out of tolerance. Should be 68 F + or - 0.5 F and the humidity should be controlled between 30 and 45 % RH. Currently, the room is above 70 F and has a relative humidity of 50%+. Please correct ASAP.
119574	9/17/01	AC	The heat is on again. Could we turn it off or down a little. Thanks.
119582	9/17/01	AC	AC in main computer room is not working properly. From refer tickets #119479, 119531
119603	9/18/01	AC	Water leaking from pipe in ceiling in shop 94203 equipment room. Just had new ceiling installed and it is getting wet. This needs immediate attention.
119617	9/18/01	AC	Evaluate and repair as necessary all pneumatic controls for vav boxes.
119630	9/18/01	AC	P/C office has water leaking from the roof shop 95775
119632	9/18/01	AC	Chill water temp too high/work stop ASE 1
119642	9/18/01	AC	Heat coming out of vents.
119644	9/18/01	AC	It's 81 degrees at my desk and rising. Please turn on the AC. Thank you!
119646	9/18/01	AC	Water is dripping from AC unit to stacker area below, where there are electrical wires. This is hazardous.
119655	9/18/01	AC	Install hot gas on AC unit for front office area.
119668	9/18/01	AC	Replace leaking valve over ASE #3 test stand. Pneumatic valve
119675	9/18/01	AC	Set the air temperature in the pmc room in bldg between 68 to 70 degrees F. It is currently 78 degrees F. Thanks!
119682	9/18/01	AC	Air dryer alarm in equipment room. High dew point.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
119697	9/18/01	AC	Hot air entering shop thru air vents
119709	9/19/01	AC	Check steam on AC unit area to cold on Mezzanine F
119711	9/19/01	AC	Water leak under the ramp, blade shop section, outside the bldg, on the bldg 137 side.
119713	9/19/01	AC	82 degrees at her desk. Too hot.
119715	9/19/01	AC	Repair refrigerant leaks in the 200 ton AC as per instructions
119730	9/19/01	AC	Repair rewire controls as per instruction
119731	9/19/01	AC	Cold in shop. Need a little heat mixed in this time.
119747	9/19/01	AC	AC for ISAAC lab not blowing cold air.
119776	9/19/01	AC	T2 won't go cold/work stop T58 #1
119794	9/19/01	AC	Check T-2 on T-58 old number 1
119806	9/19/01	AC	T2 system will not maintain 75 degrees on T58 # 1 manual fuel control test stand. Work stoppage
119825	9/20/01	AC	Check circuit breaker and wiring to unit.
119831	9/20/01	AC	AC drain plugged up, leaking water on floor of 93111a break room/ please repair ASAP, safety hazard
119862	9/20/01	AC	We have a leak in the ceiling of 159. The light fixture is full of water.
119864	9/20/01	AC	It is like an icebox in our office and the rest of the bldg seems nice and cool. Can you help us out?
119876	9/20/01	AC	Repair pneumatic controls on broken test stand.
119877	9/20/01	AC	File refrigerant reports as necessary
119878	9/20/01	AC	High temperature in instrument room in shop 94203. AC is not working properly.
119879	9/20/01	AC	Repair refrigerant leak on 200-ton compressor. See before starting job.
119880	9/20/01	AC	Pressure bldg in clean room
119883	9/20/01	AC	PM air handlers on bldg 4224.
119886	9/20/01	AC	PM air handlers.
119889	9/20/01	AC	The roof is leaking right above the tech library exit into disassembly shop 94404. Safety hazard for personnel.
119914	9/20/01	AC	Repair sensor in the air chiller as per instructions
119927	9/20/01	AC	Check oil level in Trane compressors and record readings each day. 6.3.658
119928	9/20/01	AC	Check operation of chillers second shift, take and record readings each day. 6.3.658
119929	9/20/01	AC	Check operation of chillers second shift, take and record readings each day. 6.3.658
119930	9/20/01	AC	Check operation of chillers second shift, take and record readings each day. 6.3.658
119932	9/20/01	AC	Check operation of chillers second shift, take and record readings each day. 6.3.658



Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
119972	9/21/01	AC	There are 3 vents in the cable area but air is coming out of only 1 vent and that air is not very cool. Most of the time that 1 vent does not work either.
119974	9/21/01	AC	Repair sensor in the air chiller as per instructions
119977	9/21/01	AC	Repair air handler #3 on CH-46 hanger deck, leaking
119981	9/21/01	AC	Water leaks from the ceiling air diffuser at the desk on the second floor of bldg 4188. Paper on the desk get wet, the seat of the desk chair has become discolored.
119986	9/21/01	AC	Fan belt on AHU on top of AEP room is producing and squealing noise.
119992	9/21/01	AC	AC is out in Mezzanine B. This is an enclosed office area and it is very hot.
119994	9/21/01	AC	Repair leaking backflow preventer on air handler to AC unit located outside the H-46 hangar bldg 137, Sunday, 30 sep 01, 0730-1130. O/T approved to accomplish repairs. Attn: WC-40
119995	9/21/01	AC	Repair ceiling leak over ice machine by tank tubing shop, aisle way.
120016	9/21/01	AC	Chilled water not working on test stand 4 & 5 test cell
120032	9/21/01	AC	Transfer 40 hp motor to 1384 for inventory to critical spare for the 133 cooling tower.
120036	9/21/01	AC	Upstairs, room 871, AC inoperable.
120052	9/22/01	AC	AC is not working. Shop is very hot.
120067	9/22/01	AC	Comfort air down!
120068	9/22/01	AC	AC not working in transmission shop. (is this the same area as the comfort air problem previously called in?) The other one has no grid #.
120091	9/24/01	AC	AC in clean room in 94203 has quit working. Temperature is 76 F and should be 68 + or - 1 F. This is a work stoppage.
120110	9/24/01	AC	Drain for the AC evaporator coil seems to be stopped up. Musty smell in the office. This is in the H53 E&E office.
120126	9/24/01	AC	AC not working. "it is dead."
120144	9/24/01	AC	AC lines need re-insulated, condensation is forming and dripping onto the floor. The floor is a waxed floor, so it is slippery. Safety hazard. Photo lab.
120154	9/24/01	AC	AC downstairs in avionics and logistics area is not working properly. Heard noise from mechanical room. Looked in and saw that belt is frayed.
120159	9/24/01	AC	Chiller not functioning on anodize line.
120161	9/24/01	AC	The AC for the metallurgical branch portion of the bldg is not operating correctly. There is essentially no airflow and the temperature is rising.
120182	9/24/01	AC	Need help in office area. Over eighty plus degrees. Fix thermostats in office area also.
120185	9/24/01	AC	T2 won't hold 75 degrees/work stop/ T58 #1
120189	9/24/01	AC	Secure front of building chillers (5 & 6), start rear chillers (4 & 5) start in line pump
120190	9/24/01	AC	Repair chiller

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
120212	9/24/01	AC	Replace propane tanks as per instructions.
120216	9/24/01	AC	Clogged drain causing leak in ordnance shop on first floor.
120255	9/25/01	AC	Purge air for electronics too hot
120288	9/25/01	AC	T2 won't regulate and hold at 68 degrees. Work stop.
120299	9/25/01	AC	Need airline replaced on heat exchanger. Work stop. (original ticket #120273 was submitted mechanical, maintenance said it is an AC situation.)
120300	9/25/01	AC	T2 won't go cold. Work stop. T64 mech #1
120315	9/25/01	AC	Chilled water piping leaking in paint Sermetel room, bldg 4225. POC for location.
120327	9/25/01	AC	Need AC filter changed.
120339	9/25/01	AC	Clogged drain causing leak in ordnance shop on first floor.
120344	9/25/01	AC	Repair AC in the pneumatic area
120363	9/26/01	AC	Very cold in shop. Probably in the 60's. Please mix in a little heat.
120367	9/26/01	AC	There's some type of upper pipe, or roof leak, near station 73 Remstar.
120373	9/26/01	AC	T2 won't go cold/work stop/ T64 mech #2
120375	9/26/01	AC	Need to replace belt on the blower.
120385	9/26/01	AC	Too cold in the H-46 team office. Please adjust the thermostat. They are freezing.
120392	9/26/01	AC	AHU 00934 remove and replace metal filters.
120395	9/26/01	AC	AHU-remove and replace metal filters.
120396	9/26/01	AC	Water dripping from ceiling. Slip hazard. Bldg 137, hangar 3, h46 E&E office.
120397	9/26/01	AC	Overhead AC vent has work area freezing. Can the thermostat be turned down, or something be done to keep it from coming straight down.
120413	9/26/01	AC	Make alterations on AC unit as per engineering.
120428	9/26/01	AC	AC leaking water on floor.
120430	9/26/01	AC	Troubleshoot the humidity controls for Mezzanine D cable shop. Temp is a flat line 70 F, the humidity ranges from a low of 65% to a high of 90% at night.
120431	9/26/01	AC	4-air handlers need belts replaced and grease as needed.
120432	9/26/01	AC	4 AH replace belts and grease as needed
120433	9/26/01	AC	Remove AC debris off rooftop and dispose of appropriately.
120443	9/26/01	AC	Check chillers daily.
120444	9/26/01	AC	Check AC for bearing shop daily.
120446	9/26/01	AC	T-64 mech #1 test stand the T-2 not getting cold enough: work stoppage

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
120470	9/26/01	AC	T2 system on T64 # 1 manual fuel control test stand inoperable. Work stoppage
120483	9/27/01	AC	Chilled water problems ASE 1
120489	9/27/01	AC	T-64 mech #1 test stand the T-2 not getting cold enough: work stoppage
120490	9/27/01	AC	AC is out. Environmentally controlled.
120491	9/27/01	AC	Need to replace belt on the blower.
120492	9/27/01	AC	AC leaking water on floor.
120503	9/27/01	AC	One of the AC units in the lab is repeatedly experiencing a low-pressure failure. Have tried to reset several times and unit continues to fail. AC is critical to our operations in that lab.
120511	9/27/01	AC	Turn on the heat to the 53 paint hanger need temperature up to dry paint
120533	9/27/01	AC	AC not cooling properly (I.E. not controlling humidity) for the AEP enclosure. Unit located on top of platform above enclosure.
120534	9/27/01	Vents	Vent motor in paint booth will not run due to broken fan belt. Replace belt for motor.
120548	9/27/01	AC	Repair refrigerator on the C46 deck.
120549	9/27/01	AC	Temperature controller inoperable/work stop
120571	9/27/01	AC	Fan making a lot of noise when running - reported from personnel using VTC equipment in main conference room.
120576	9/27/01	AC	Replace humidistat and thermostat in wall mounted temp/humid graph
120603	9/28/01	AC	Temperature controller inoperable/work stop/
120611	9/28/01	AC	Replace humidistat and thermostat in wall mounted temp/humid graph.
120644	9/28/01	AC	No AC, not working!
120663	9/28/01	AC	The AC system not working in the 96300 training room area in bldg 133. Request the AC be checked and turned on to cool the classroom. Thanks.
120666	9/28/01	AC	AC not working properly, smells of burnt oil
120686	9/28/01	AC	Check oil level in Trane compressors and record readings each day. 6.3.658
120687	9/28/01	AC	Check operation of chillers second shift, take and record readings each day. 6.3.658
120688	9/28/01	AC	Check operation of chillers second shift, take and record readings each day. 6.3.658
120689	9/28/01	AC	Check operation of chillers second shift, take and record readings each day. 6.3.658
120690	9/28/01	AC	Check operation of chillers second shift, take and record readings each day. 6.3.658

TE 3.32 – HVAC&R Repair Work Orders